



Department of Public Works

**Ghassan Korban**  
Commissioner of Public Works

**Preston D. Cole**  
Director of Operations

Official Notice # 100

Addendum No. 1

Special Provision 36 Decorative Railing Bridge Item SPV.0105.01

Section B.1 Stainless Steel is amended to specify Grade 316 stainless steel.

Plan Sheet 83 General Notes, Design Data and List of Drawings

Structural Steel-Bridge Railing note is amended to specify Grade 316 stainless steel.

Plan Sheet 107 Railing Details 2 of 3

Detail 3-The  $\frac{3}{4}$ " x  $1\frac{1}{2}$ " horizontal bar rail does not require the chamfered edges.

Very truly yours,

Michael Loughran

Coordination Manager

