

ADDENDUM NO. 1

This Addendum consists of the following **CHANGES TO THE BID DOCUMENTS FOR OFFICIAL NOTICE 14-2011**:

1. In the Specifications for WP-306: Ozone Cooling Water Booster Pump Replacement at the Linnwood Purification Plant, make the following changes:
  - a. **Specifications, Exhibit “A”, Technical Specifications, Section 11000, Equipment:**

**INSERT: FIGURE E-1 AT END OF SPECIFICATION**

END OF ADDENDUM NO.1


480V 3P  
PRIMARY POWER SOURCE  
FROM MCCIA

480V 3P  
SECONDARY POWER SOURCE  
FROM PANEL P-8

OZONE COOLING WATER  
BOOSTER PUMP SKID

CONTROL PANEL

EXISTING  
PLANT HMI  
FACTORY TALK SE  
SWITCH ROOM



Cat5e  
Ethernet

