



Department of Public Works
Infrastructure Services Division

Ghassan Korban
Commissioner of Public Works

Preston D. Cole
Director of Operations

Jeffrey S. Polenske
City Engineer

February 22, 2016

Subject: Official Notice No. 16-1-2016

7TH District Police Station
RTU's Replacement
3626 West Fond Du Lac Avenue
Milwaukee, Wisconsin

For which bid will be received on
Tuesday, March 1, 2016

Addendum No. 1

- A. In regard to our advertisement for the 7th District Police Station, RTU's Replacement, located at 3626 West Fond Du Lac Avenue, Milwaukee, Wisconsin this attached Addendum No. 1 is issued to modify the original documents and is hereby made part of the proposal.
- B. Each bidder shall read the entire addendum. Proposals shall include all items included in this Addendum No. 1.

Very truly yours,

Thomas E. Tarkowski
Bridges and Buildings



Official Notice No. 16-1-2016

7TH District Police Station
RTU's Replacement
3626 West Fond Du Lac Avenue
Milwaukee, Wisconsin

Addendum No. 1

IMMEDIATELY UPON RECEIPT OF THE ADDENDUM, PLEASE SIGN THIS RECEIPT AND FAX BACK TO DPW-BRIDGES AND BUILDINGS SECTION AT (414) 286-5907 OR EMAIL (dpitts@milwaukee.gov).

Company Name

Name

Date



ADDENDUM #1

February 19, 2016

Official Notice No. 16-1-2016
7TH District Police Station
RTU's Replacement
3626 West Fond Du Lac Avenue
Milwaukee, Wisconsin

In the Invitation to Bid:

Alternate No. 4:

State the amount to be added to the Base Bid to perform all work and furnish all materials for the following items as denoted below:

Replace Controls Head End

- a. Replace existing Trane Tracer BCU with bridge, SE controller and Ethernet switch. All existing equipment on the BCU shall be migrated into the new SE controller and provided with new graphics interface at the Police Administration Building (4 PCs).

Revise to Read:

Alternate No. 4:

State the amount to be added to the Base Bid to perform all work and furnish all materials for the following items as denoted below:

Replace Controls Head End

- a. Replace existing Trane Tracer BCU with a Bridge and SC controller. All existing equipment on the BCU shall be migrated into the new SC controller and provided with new graphics interface at the Police Administration Building (4 PCs).
- b. If Alternate No. 2 is selected in conjunction with this alternate scope, the Bridge will not be required.
- c. The City of Milwaukee will provide a new data drop to the existing BCU location in the lower level mechanical room for connection to the Bridge.

In the Project Manual:

Section 00100/2 – "INSTRUCTION TO BIDDERS"

Alternate No. 4:

State the amount to be **added** to the Base Bid to perform all work and furnish all materials for the following items as denoted below:



Replace Controls Head End

- a. Replace existing Trane Tracer BCU with bridge, SE controller and Ethernet switch. All existing equipment on the BCU shall be migrated into the new SE controller and provided with new graphics interface at the Police Administration Building (4 PCs).

Revise to Read:

Alternate No. 4:

State the amount to be **added** to the Base Bid to perform all work and furnish all materials for the following items as denoted below:

Replace Controls Head End

- a. Replace existing Trane Tracer BCU with a Bridge and SC controller. All existing equipment on the BCU shall be migrated into the new SC controller and provided with new graphics interface at the Police Administration Building (4 PCs).
- b. If Alternate No. 2 is selected in conjunction with this alternate scope, the Bridge will not be required.
- c. The City of Milwaukee will provide a new data drop to the existing BCU location in the lower level mechanical room for connection to the Bridge.

Section 01010/2, paragraph 2A; subparagraph 5 – "SUMMARY OF WORK"

5. **Alternate No. 4:**

Replace Controls Head End

- a) Replace existing Trane Tracer BCU with bridge, SE controller and Ethernet switch. All existing equipment on the BCU shall be migrated into the new SE controller and provided with new graphics interface at the Police Administration Building (4 PCs).

Revise to Read:

5. **Alternate No. 4:**

Replace Controls Head End

- a) Replace existing Trane Tracer BCU with a Bridge and SC controller. All existing equipment on the BCU shall be migrated into the new SC controller and provided with new graphics interface at the Police Administration Building (4 PCs).
- b) If Alternate No. 2 is selected in conjunction with this alternate scope, the Bridge will not be required.
- c) The City of Milwaukee will provide a new data drop to the existing BCU location in the lower level mechanical room for connection to the Bridge.