



Department of Public Works  
Building Services Division

Ghassan Korban  
Commissioner of Public Works  
Preston D. Cole  
Director of Operations  
Jeffrey S. Polenske  
City Engineer

December 12, 2011

Subject: Official Notice No. 172  
Reroofing of Sanitation Facility South Area 1  
Office/Storage, Garage and Salt Shed Buildings  
Also as Alternate Bid  
Window & Door Replacement of  
Sanitation Facility-South Area 1 Office Building  
2363 South 35<sup>th</sup> Street  
Milwaukee, Wisconsin  
For which bid will be received on  
Thursday, December 15, 2011 at 10:30 a.m.

Addendum No. 2

Gentlemen:

- A. In regard to our advertisement for the Reroofing of Sanitation Facility South Area 1 Office/Storage, Garage and Salt Shed Buildings Also as Alternate Bid Window & Door Replacement of Sanitation Facility – South Area 1 Office Building, 2363 S. 35<sup>th</sup> Street Milwaukee, Wisconsin, this attached Addendum No. 2 is issued to modify the original documents and is hereby made part of the proposal.
- B. Each bidder shall read the entire addendum. Proposals shall include all items included in this Addendum No. 2.

Very truly yours,

PAUL R. FREDRICH  
Facilities Manager  
Facilities Development & Management Section



Ghassan Korban  
Commissioner of Public Works  
Preston D. Cole  
Director of Operations  
Jeffrey S. Polenske  
City Engineer

Department of Public Works  
Infrastructure Services Division

Official Notice No. 172  
Reroofing of Sanitation Facility South Area 1  
Office/Storage, Garage and Salt Shed Buildings  
Also as Alternate Bid  
Window & Door Replacement of  
Sanitation Facility-South Area 1 Office Building  
2363 South 35<sup>th</sup> Street  
Milwaukee, Wisconsin  
Addendum No. 2

IMMEDIATELY UPON RECEIPT OF THE ADDENDUM, PLEASE SIGN THIS RECEIPT  
AND FAX BACK TO ISD – FACILITIES DEVELOPMENT AND MANAGEMENT  
SECTION AT (414) 286-5907.

Company Name

Name

Date

---

**ADDENDUM No. 2**  
**December 12, 2011**

Official Notice No. 172  
Reroofing Of Sanitation Facility South Area 1  
Office/Storage, Garage And Salt Shed Buildings  
Also as Alternate Bid  
Window & Door Replacement Of  
Sanitation Facility – South Area 1 Office Building  
2363 S 35th Street  
Milwaukee, Wisconsin.

Groth Design Group Project No.: 11.032.2

This addendum consists of one (1) page of text and one (1) supplemental 8 ½" x 11" drawing (R-1). Please attach this addendum to the drawings and project manual in your possession.

**1. DRAWINGS**

A. Sheet A7.1 ROOF PLAN

**Revision – Detail 4/A7.1:**

See attached supplemental detail drawing R-1.

B. Sheet A7.1, ROOF PLAN

**Revision – Roof Plan Salt Shed 2/A7.1:**

Existing plan note reading as follows:

"EXISTING TAR AND GRAVEL BUILT-UP ROOF TO BE REMOVED. CONTRACTOR TO REMOVE ENTIRE EXISTING ROOF DECK AND INSTALL NEW 3/4" T&G TREATED PLYWOOD DECKING AND FULLY ADHERED EPDM MEMBRANE"

Shall be revised to read:

"EXISTING TAR AND GRAVEL BUILT-UP ROOF TO BE REMOVED. CONTRACTOR TO REMOVE ENTIRE EXISTING ROOF DECK AND INSTALL NEW 3/4" TREATED PLYWOOD DECKING AND FULLY ADHERED EPDM MEMBRANE"


**END OF ADDENDUM NO. 2**

ADDENDUM #2  
PAGE 1 OF 1


ADDITIONS AND ALTERATIONS TO:  
CITY OF MILWAUKEE SANITATION FACILITY  
2363 SOUTH 35TH STREET  
MILWAUKEE, WI 53215

**GROTH DESIGN GROUP**

PROJECT NO. 11 032.2  
PLAN DATE: 10.18.11  
REVISION DATE: 12/09/11



NOTE: EXISTING ROOF DECK SLOPES, INSULATION SHOULD BE UNIFORM THICKNESS ACROSS ENTIRE ROOF.



**AD-1 ROOF EDGE DETAIL - GARAGE**

1 1/2" = 1'-0"

ADDENDUM 02  
REF. 4/A7.1

**DRAWING R-1**