

June 2, 2016

CITY OF MILWAUKEE
DEPARTMENT OF PUBLIC WORKS
MILWAUKEE WATER WORKS

June 2, 2016

OFFICIAL NOTICE NO. 46-1-2016

PROJECT 1

ADDENDUM NO. 1

NOTICE TO CONTRACTORS intending to bid on Official Notice Number 46-1-2016, which appeared in the Daily Reporter on Tuesday, May 24, 2016, with a Bid Opening Date on Tuesday, June 7, 2016.

The purpose of this addendum is to provide updated information to supersede and change the Contract Documents for Project HP-183.

PROJECT SPECIFICATIONS

1. **SECTION 07511 Built-Up Asphalt Roofing**; Part 2 Products; 2.03 Description of System and Performance Requirements; A

DELETE 6. Surfacing: flood coat of cold or hot process coal tar pitch bitumen and roofing aggregate consisting of pea gravel and white spar.

ADD 6. Surfacing: flood coat of SEBS modified roofing asphalt and roofing aggregate consisting of pea gravel and white spar.

June 2, 2016

2. **SECTION 07511 Built-Up Asphalt Roofing;** Part 2 Products; 2.07 Asphalt Materials

DELETE D. Final Surfacing Adhesive: SEBS polymer modified, coal tar pitch adhesive.

ADD D. Final Surfacing Adhesive: SEBS modified roofing asphalt

NOTE: The contractor shall acknowledge receipt of Addendum Number 1 on page 9 of the Bid Document titled “ACKNOWLEDGEMENTS PAGE.”

END OF ADDENDUM NO. 1