

17.8 ADDENDUM NO. 1 Architectural and Structural Drawings Notations

1. Sheet R-163-A-1

a. Add the following note:

“8. DEMO AND REMOVE THE FLOOR TILE AND ASSOCIATED MASTIC IN ROOM 117.”

2. Sheet R-163-A-4

a. Replace the two callouts between Column Rows C and F that read “INFILL CMU AT BASE WALL AS NEEDED AT HVAC LOUVER PENETRATION – SEE ELEVATION SHEET A-3 AND HVAC SHEETS” with the following callouts:

“INFILL STUCCO TEXTURED METAL PANEL AT BASE WALL AS NEEDED AT HVAC LOUVER PENETRATION – SEE ELEVATION SHEET A-3 AND HVAC SHEETS.”

3. Sheet R-163-S-10

a. Add the following note:

“2. DO NOT REMOVE THE EXISTING DRAINAGE TRENCH COVERS FOR THE AREAS NOT COVERED BY THE ENGINE GENERATOR FOUNDATION.”

b. Add the following note:

“3. CUT THE EXISTING DRAINAGE TRENCH COVERS AS REQUIRED TO PROVIDE PARTIAL TRENCH COVERS AS NEEDED TO COVER PORTIONS OF DRAINAGE TRENCH THAT WILL NOT BE COVERED BY THE ENGINE GENERATOR FOUNDATION.”

c. Add the following note:

“4. CUT THE EXISTING CONVEYOR TRENCH COVERS AT THE NORTH AND SOUTH ENDS OF THE WORK AS REQUIRED TO PROVIDE PARTIAL TRENCH COVERS AS NEEDED TO COVER THE PORTIONS OF THE CONVEYOR TRENCH THAT WILL NOT BE FILLED WITH CONCRETE.”

d. Add the following note:

“5. THE COAL CONVEYOR TRENCH IS FILLED WITH BRICKS AND OTHER DEBRIS. REMOVE BRICKS AND DEBRIS FROM THE AREAS OF TRENCH TO BE FILLED WITH CONCRETE.”

4. Sheet R-163-S-12

- a. Add the following note:

“NOTES:

- 1. “SCREENED” DELINEATION SHOWN ON THIS SHEET DENOTES EXISTING FACILITIES. “SCREENED” INFORMATION WAS TAKEN FROM PREVIOUS CONSTRUCTION DRAWINGS, IS FOR REFERENCE ONLY AND SHALL BE FIELD VERIFIED.”

5. Sheet R-163-S-14

- a. Delete the callout between Column Rows J and K that reads “STAIR TO REMAIN ABOVE.”

6. Sheet R-163-E-6

- a. Add the following note:

“NOTES:

- 1. TRIP AND CLOSE CONTROLS AND INDICATING LIGHTS SHALL BE FURNISHED FOR ALL BREAKERS AS SPECIFIED IN SECTION 16345, PARAGRAPH 2-2.25.O, WHETHER INDICATED GRAPHICALLY ON THIS SHEET OR NOT. THE TRIP AND CLOSE CONTROLS AND INDICATING LIGHTS FOR NON-GENERATOR BREAKERS SHALL BE LOCATED IN SECTION 2 OF THE GENERATOR SWITCHGEAR.”

7. Sheet R-163-I-6

- a. Replace both piping designations that read “4”-SW-CS” in the JACKET WATER LOOP with the following designations:

“6”-SW-CS.”