

October 23, 2012

CITY OF MILWAUKEE
DEPARTMENT OF PUBLIC WORKS
MILWAUKEE WATER WORKS

ADDENDUM NO. 2

The purpose of this addendum is to provide updated information to supersede and change the Contract Documents for HP-179.

PROJECT SPECIFICATIONS

1. **SPECIFIC OFFICIAL NOTICE NO. 56-2012**

REMOVE “Sealed bids will be opened on Thursday, October 25, 2012 at 10:30 A.M. CDT...”

INSERT “Sealed bids will be opened on Wednesday, October 31, 2012 at 10:30 A.M. CDT...”

2. **INVITATION TO BID**

REMOVE “...no later than Thursday, October 25, 2012 at 10:30 A.M.”

INSERT “...no later than Wednesday, October 31, 2012 at 10:30 A.M.”

3. **SECTION 02220 Demolition, 3.03 Demolition**

ADD H. Existing openings in floor for piping and ductwork that are not reused shall be filled and patched. Smaller openings shall be filled with mortar or concrete and covered with a floor covering that matches existing. Color of floor covering need not match existing floor coverings exactly. Openings larger than 12-inches in diameter shall have rebar installed.

October 23, 2012

ADD I. The COMPRESSOR ROOM's ceiling tested positive for asbestos. The COMPRESSOR ROOM is located in the basement.

4. **SECTION 15060 Pipe & Accessories**, 3.03 Installation

ADD B20. Bids shall assume that vertical steam piping which is located inside chases is in good condition and can be reused. Connections from vertical piping to steam terminal equipment and take offs from steam main piping shall be new. Actual condition of vertical piping will be evaluated during time of construction.

5. **SECTION 16510 Interior Luminaires**, 2.02 Exit/Emergency Lights:

REMOVE H1. Combination units shall be equipped with two (2) fully adjustable, 6 V., 3.9 watt, tungsten (T5 wedge base) lighting heads.

INSERT H1. Combination exit lights and emergency units shall be equipped with two (2) fully adjustable, 6 V., 3.9 watt, tungsten (T5 wedge base) lighting heads.

NOTE: ADDENDUM NO. 3 will be placed on-line Wednesday, October 24, 2012.

END OF ADDENDUM NO. 2