



Department of Public Works
Infrastructure Services Division

Ghassan Korban
Commissioner of Public Works

Preston D. Cole
Director of Operations

Jeffrey S. Polenske
City Engineer

June 1, 2012

**OFFICIAL NOTICE NUMBER 77-2012
PROJECT NUMBER TD03484000**

ADDENDUM NUMBER 1


NOTICE TO CONTRACTORS intending to bid on Official Notice Number 77-2012, which appeared in the Daily Reporter, with a Bid Opening date of Thursday, June 7, 2012 at 10:30 a.m.

1. Regarding specification section 02459-4, 3.3 INSTALLATION, subsection K, revise the last sentence to read, "Place concrete full depth of pile. Vibrate the top five feet in pile".
2. Several references to sealed interlocks are made in Specification Section 02462 – STEEL SHEET PILING. Sealed interlocks are not necessary for the dockwall. References to sealed interlocks in specification section 02462 can be omitted.
3. Remove specification section 02462-10 3.8 COAL TAR EPOXY (sheet piling), and all references to coal tar epoxy for the sheet piling. Coal tar epoxy will not be used on this project.
4. For clarification, the sheet pile dockwall will be installed in front of (river side) the existing wood dockwall. Per the amendment to the Department of Natural Resources permit for this project, this project is authorized to "install a 40 foot section of steel sheet pile wall immediately adjacent to the deteriorating wood piling wall on the bank of the river."

All other bid conditions remain unchanged.

NOTE: Each contractor shall acknowledge receipt of Addendum Number 1 on page 8 (Acknowledgements Page) in the Invitation to Bid.

Very truly yours,


Jeffrey S. Polenske
City Engineer

CSL/jmw