



Department of Public Works  
Infrastructure Services Division

June 11, 2012

**OFFICIAL NOTICE NUMBER 77-2012  
PROJECT NUMBER TD03484000**

**ADDENDUM NUMBER 3**

**Ghassan Korban**  
Commissioner of Public Works

**Preston D. Cole**  
Director of Operations

**Jeffrey S. Polenske**  
City Engineer

NOTICE TO CONTRACTORS intending to bid on Official Notice Number 77-2012, which appeared in the Daily Reporter, with a Bid Opening date of Thursday, June 14, 2012 at 10:30 a.m.

1. **Revise all references to PSL/parallel strand lumber and OSB/oriented strand board on the contract drawings to pressure-treated glued laminated (glulam) lumber. Sizes of lumber shall be modified as follows:**
  - **References to 7 X 18 PSL shall be replaced with 6- $\frac{3}{4}$ " X 18" glue laminated lumber.**
  - **References to 3 $\frac{1}{2}$ " X 9 $\frac{1}{4}$ " PSL shall be replaced with 3 $\frac{1}{4}$ " X 9" glue laminated lumber.**
  - **References to 1 $\frac{3}{4}$ " X 5 $\frac{1}{2}$ " oriented strand board shall be replaced with 2 $\frac{1}{2}$ " X 6" glue laminated lumber.**
2. **Replace Invitation to Bid page 6 (Bid Forms – Item Sheets) with the attached page 6a and 6b.**
3. **Add line item D: Flowable Fill/Slurry. Flowable fill shall be used to backfill behind the new steel sheeting. Product shall be a flowable fill (slurry) or lean mix of 200-300 psi and be paid for on a cubic foot basis.**
4. **Regarding specification section 02459-3, 2.1 MATERIALS, subsection A, oil field pipe shells can be replaced with a typical 12" X  $\frac{1}{2}$ " wall pipe.**

All other bid conditions remain unchanged.

NOTE: Each contractor shall acknowledge receipt of Addendum Number 1 through 3 on page 8 (Acknowledgements Page) in the Invitation to Bid.

Very truly yours,



Jeffrey S. Polenske  
City Engineer

CSL/jmw

**OFFICIAL NOTICE NO. 77**

Description: This project involves driving of piling, tied back sheet pile dockwall, structural steel, wood structures, ironwood decking, decorative steel railings, lighting, asphalt paving, and chain link fencing, and additional work as detailed in the contract drawings and specifications.

Note: Bid item cost for quantities in lineal feet **must** be written as a unit cost; not the total cost.

**ALL BIDS MUST BE TYPED OR PRINTED**

**BASE BID**

<u>Item</u>	<u>Description</u>	<u>Quantity</u>
<b>A</b>	<b>Riverwalk Connector</b> (Lump sum pricing excluding sheet piling and concrete-filled steel piling)	<b>1 lump sum</b>
(Bid in figures) \$	_____	lump sum
(Bid in words) \$	_____	lump sum
<b>B</b>	<b>Section 02459: Concrete Filled Steel Piles</b>	<b>880 lineal feet</b>
(Bid in figures) \$	_____	per lineal foot
(Bid in words) \$	_____	per lineal foot
<b>C</b>	<b>Section 02462: Steel Sheet Piling</b>	<b>40 lineal feet</b>
(Bid in figures) \$	_____	per lineal foot
(Bid in words) \$	_____	per lineal foot
<b>D</b>	<b>Flowable Fill/Slurry</b>	<b>750 cubic feet</b>
(Bid in figures) \$	_____	per cubic foot
(Bid in words) \$	_____	per cubic foot

**TOTAL BASE BID AMOUNT**

(Total Bid in Figures) \$ \_\_\_\_\_

(Total Bid in Words) \$ \_\_\_\_\_

**BID ACCEPTANCE:**

The Commissioner of Public Works shall award the contract based on the Base Bid only.