



Department of Public Works
Infrastructure Services Division

Ghassan Korban
Commissioner of Public Works

Preston D. Cole
Director of Operations

Jeffrey S. Polenske
City Engineer

May 28, 2015

Subject: Official Notice No. 78-1-2015

MPD – Data Room UPS units & Cooling Replacement
Various locations
Milwaukee, Wisconsin

For which bid will be received on
Monday, June 1, 2015

Addendum No. 3

- A. In regard to our advertisement for the MPD – Data Room UPS Units & Cooling Replacement, Various locations Milwaukee, Wisconsin this attached Addendum No. 3 is issued to modify the original documents and is hereby made part of the proposal.
- B. Each bidder shall read the entire addendum. Proposals shall include all items included in this Addendum No. 3.

Very truly yours,

Paul R. Fredrich, Facilities Operations Manager
Bridges and Buildings



Official Notice No. 78-1-2015

MPD – Data Room UPS Units & Cooling Replacement
Various locations
Milwaukee, Wisconsin

Addendum No. 3

IMMEDIATELY UPON RECEIPT OF THE ADDENDUM, PLEASE SIGN THIS RECEIPT AND FAX BACK TO DPW-BRIDGES AND BUILDINGS SECTION AT (414) 286-5907 OR EMAIL (Thomas.tarkowski@Milwaukee.gov).

Company Name

Name

Date



DRAWINGS

1. Revise the following Mechanical drawings as follows:
 - a. Sheet N10-M1, Detail 2 – CRAC Unit Piping Detail
 - i. Replace Note 6 with the following:

“The contractor shall coordinate the unit start-up with the city’s control contractor to integrate the new units with the building automation system. All integration control work associated with the HVAC units shall be by the city.”
 - b. Sheet N13-M1, Detail 2 – CRAC Unit Piping Detail
 - i. Replace Note 6 with the following:

“The contractor shall coordinate the unit start-up with the city’s control contractor to integrate the new units with the building automation system. All integration control work associated with the HVAC units shall be by the city.”
 - c. Sheet N14-M1, Detail 2 – CRAC Unit Piping Detail
 - i. Replace Note 6 with the following:

“The contractor shall coordinate the unit start-up with the city’s control contractor to integrate the new units with the building automation system. All integration control work associated with the HVAC units shall be by the city.”
 - a. Sheet S7-M1, Detail 2 – CRAC Unit Piping Detail
 - i. Replace Note 6 with the following:

“The contractor shall coordinate the unit start-up with the city’s control contractor to integrate the new units with the building automation system. All integration control work associated with the HVAC units shall be by the city.”

END OF Addendum #3