City of Milwaukee

Department of Public Works

Infrastructure Services Division
Facilities Development and Management Section

R. A. ANDERSON WATER TOWER AND MUNICIPAL BUILDING
REROOFING OF THE 1st. 2ND AND 3RD FLOOR ROOFS

4001 S. 6TH STREET
Milwaukee, Wisconsin 53221

April 2012

Project Number BU11091371

Official Notice No. 88

CITY OF MILWAUKEE, WISCONSIN

DEPARTMENT OF PUBLIC WORKS

INFRASTRUCTURE SERVICES DIVISION

FACILITIES DEVELOPMENT AND MANAGEMENT SECTION

PROJECT MANUAL

GOVERNING THE

R. A. ANDERSON WATER TOWER AND MUNICIPAL BUILDING

REROOFING OF THE 1st. 2ND AND 3RD FLOOR ROOFS
4001 S. 6th Street

MILWAUKEE, WISCONSIN 53221

Project No. BU11091371

April, 2012

Official Notice No. 88

TABLE OF CONTENTS

CITY OF MILWAUKEE
GENERAL OFFICIAL NOTICE
TO CONTRACTORS

Separate sealed bids for each project will be received until 10:30 A.M. of the bid opening date at which time bids will be publicly opened and read for furnishing all material and doing all work for each project in accordance with the requirements of the respective Official Notice on the bid form furnished in accordance with plans, specifications, contract documents, and proposed form of contract on file in the office of the Department of Public Works, Municipal Building, 841 N. Broadway, Room 506, Milwaukee, Wisconsin, 53202.

PROSPECTIVE BIDDERS ARE TO CAREFULLY EXAMINE AND REVIEW ALL CONTRACT DOCUMENTS AND MATERIALS IN SAID OFFICE BEFORE SUBMITTING BID.

AFFIDAVITS OF NO INTEREST MUST ACCOMPANY THE BIDS, AND THE FAILURE OF PROSPECTIVE BIDDERS TO COMPLY WITH THESE REQUIREMENTS MAY DISQUALIFY THE BID.

THE CONTRACTOR/LESSEE AGREES TO COMPLY WITH ALL APPLICABLE REQUIREMENTS OF THE AMERICANS WITH DISABILITIES ACT OF 1990, 42 U.S.C. § 12101, ET. SEQ. THE TDD NUMBER FOR PUBLIC WORKS IS (414) 286-2025.

As part of the bid each bidder shall submit a list of anticipated subcontractors and the class of work to be performed by each, which list should not be added to nor altered without the written consent of the Commissioner of Public Works.

All contractor(s) and subcontractor(s) are required to furnish or have on file a certificate of insurance in accordance with the insurance provisions of the General Specifications.

All contractor(s) and subcontractor(s) are subject to the prevailing wage rates and hours of labor as prescribed by the Common Council of the City of Milwaukee consistent with provisions of Section 66.293 of the Wisconsin Statutes.

Copies of the actual work classifications and wage and fringe benefit rates enforced on this project are available in Room 506 of the Municipal Building.

Corporate surety will be required on performance and payment bonds for all projects listed in the following Official Notices. All applicable charter and Statutory provisions and ordinances, all the provisions of this official notice, invitation to bid, general and detailed specifications, special provisions, proposal, schedule of fixed prices, addendum and plans for this project and all other contract documents set forth in the invitation to bid will be incorporated and made part of the contract as if therein set forth in full.

Tie bids, when the lowest ones, will be decided by the Commissioner of Public Works.

The Commissioner of Public Works reserves the right to reject any or all bids.

Signed: GHASSAN KORBAN
Commissioner of Public Works

Countersigned: W. MARTIN MORICS,
City Comptroller

CITY OF MILWAUKEE
SPECIFIC OFFICIAL NOTICE NO. 88

Important Notice:

The Invitation to Bid, all bid documents and the Plans & Specifications for the project listed will be available electronically to prospective bidders via **http://www.mpw.net/bids/docs/88-2012.** Any required addenda or responses related to the listed projects will be posted on said website. Bidders are encouraged to utilize this electronic method of obtaining bid documents as the Department of Public Works intends to solely use this method for future projects. At this time however, a limited number of hard copies of the above documents will also be available at address listed below. **IF YOU ONLY PRINT THE DOCUMENTS FROM THE WEBSITE AND WOULD LIKE YOUR COMPANY'S NAME PLACED ON THE PLAN HOLDERS' LIST, PLEASE CALL 414-286-3314.**

Sealed bids will be opened on Tuesday, June 19, 2012 at 10:30 A.M. for the **R.A. ANDERSON WATER TOWER AND MUNICIPAL BUILDING, RE-ROOFING OF THE 1ST, 2ND AND 3RD FLOOR ROOFS**, **located at 4001 South 6th Street, Milwaukee WI 53221.**

Bid Security Required: Bond, Certified Check, Cashier's Check, or Cash to accompany bid: 10% of Contractor's Base Bid

Time for Completion: 80 Working Days.

Liquidated Damages, per diem: $150.00

The MWSBE requirement for this project is 25% of the contract base bid: (**SBE 25%)**

The residency requirement for this project is 40% of all hours worked on the project.

The apprenticeship requirements for this project are: **1**

Roofer, Waterproofer

The contractor shall specifically note the MWSBE, residency, and apprenticeship forms for this project. If the forms are not filled out properly, it will be cause for rejection of the bid.

Plans and project manual will be furnished to the prospective bidders upon payment of a $10.00 non-refundable fee in room 506, Frank P. Zeidler Municipal Building, 841 North Broadway, Milwaukee, Wisconsin 53202. For general questions call 414-286-3314.

A $10.00 per set additional non-refundable fee is required to obtain bid documents by mail. Plans are sent via U.S. mail unless other arrangements are made by the contractor.

Contractor must comply with all provisions of the CITY OF MILWAUKEE GENERAL OFFICIAL NOTICE TO CONTRACTORS published herein and at http://mpw.milwaukee.gov/services/bids_home

Pre-Bid Meeting: A Pre-Bid Meeting is scheduled for Tuesday, June 12, 2012, at 2:00 p.m. in Room 606 of the Frank P. Zeidler Municipal Building, 841 North Broadway, Milwaukee, Wisconsin. Bidder participation is urged to become familiar with all aspects of the project and bidding requirements.

Signed:

_____

GHASSAN KORBAN
Commissioner of Public Works

PUBLISH SIX (6) TIMES INSERTION WITHOUT FAIL, Tuesday, June 05, 2012

SECTION 00100: INSTRUCTIONS TO BIDDERS

See also Instructions to Bidders in the "General Specifications" of the Department of Public Works, City of Milwaukee, Wisconsin, dated January 31, 1992, and all subsequent addenda.

BID FORM:

Submit lump sum prices for the work as indicated on the drawings and specified herein, complete in every respect.

Bids will not be accepted in any form except on the bid form included with this project manual.

The contractor must recognize and abide by the right of the Owner (City of Milwaukee) to accept or reject any or all bids in the best interests of the City.

ALTERNATE BIDS:

Each bidder shall examine the plans and project manual thoroughly to determine what extent the Alternates will affect the Bid.

Alternate Bid 1: Remove and Replace Existing Second Floor Roofing

Provide a lump sum price to remove and replace existing roofing materials, insulation and accessories on the second floor roof, as indicated in the plans and project manual.

INFORMATIONAL PRICES

Informational Price A-1:

Provide a lump sum price for general conditions and contractors fee including mobilization, staging, etc.

Informational Price B-1:

Provide a lump sum price for swing stage, and public and site protection.

Informational Price C-1:

Provide a lump sum price for removing the third floor built up roof, insulation and accessories.

Informational Price D-1:

Provide a lump sum price for installing waterproof membrane, insulation, built up roof and accessories on the third floor roof.

UNIT PRICES:

Each bidder shall provide on the bid proposal the following unit prices that were used in arriving at the base bid. The unit prices will be used for additions or deductions under the contract.

Unit Price A:

State the unit price for 100 s.f. for installing waterproof membrane, insulation, built up roofing and accessories on each of the NE and SE first floor roofs.

Unit Price B:

State the unit price for 100 s.f. for installing waterproof membrane, insulation, built up roofing and accessories on the SW first floor roof.

Unit Price C:

State the unit price for 100 s.f. for installing waterproof membrane, insulation, built up roofing and accessories on the NW first floor roof.

CONTRACT AWARD:

The Commissioner of Public Works will award the contract on the basis of the Base Bid only or the Base Bid and the Alternate Bid(s) as funds permit.

CONTRACT BREAKDOWN:

Shortly after the award of the contract, each contractor shall submit a list showing the cost breakdown of the items in his contract. This list will be used as a basis for estimates of work completed for partial payment.

SITE VISIT:

All contractors shall visit the site, consult the drawings and project manual, be familiar with the work of other contractors and determine for themselves all conditions affecting the work.

Failure by a contractor to be familiar with the project shall not release him from any obligation under this contract to complete the work in strict conformity with the plans and project manual and all City, State and Federal Codes or regulations pertaining to the work.

CONSTRUCTION START AND COMPLETION DATES:

The TOTAL WORKING DAYS are stated in the Specific Official Notice. The contractor may begin procuring materials and off-site fabricating (as appropriate and approved by Architect) on the date stated on the Notice to Proceed. The Notice to Proceed will be sent to the contractor directly following the signing of the contract.

BASE BID EXCLUSIONS:

None at this time.

CONTRACT BREAKDOWN:

Shortly after the award of the contract, each contractor shall submit a list showing the cost breakdown of the items in his contract. This list will be used as a basis for estimates of work completed for partial payment.

ADDITIONAL PLANS/PROJECT MANUALS

The successful contractor will be responsible for furnishing all additional copies of plans, project manuals, addenda, etc., as may be needed by the contractor and subcontractors. The City will cooperate by making originals available to the contractor's printer of choice.

END OF SECTION

SECTION 00700: GENERAL CONDITIONS

1. SCOPE:

   A. Index:

      1. Scope
      2. DPW General Specifications
      3. Definitions
      4. Control of Work and Materials
      5. Samples and Tests
      6. Project Coordination
      7. Supervision of Work
      8. Technical Specifications and Drawings
      9. Safety Regulations
      10. Code Rules

2. Department of Public Works General Specifications:

   Provisions of the Department of Public Works General Specifications dated January 31, 1992, and subsequent addenda except as may be modified or expanded upon in this project manual, shall apply to all contractors and subcontractors working on the project. Copies of the General Specifications may be obtained from the Department of Public Works General Office, Room 501 Zeidler Municipal Building, 841 North Broadway, Milwaukee, Wisconsin, or from the FACILITIES DEVELOPMENT AND MANAGEMENT SECTION, Room 602, Zeidler Municipal Building.

3. Definitions:

   A. Owner: City of Milwaukee.

   B. Facilities Manager: The Facilities Manager of FACILITIES DEVELOPMENT AND MANAGEMENT SECTION.

   C. Project Inspector: The authorized representative of the Commissioner assigned to make detailed inspection of any or all portions of the work and materials thereof. These inspections are not a substitute to those required by the Department of Neighborhood Services for permit and code compliance.

   D. Addenda: Written or graphic instruments issued prior to the execution of the contract which modify or interpret the bidding documents, including drawings and project manual by additions, deletions, clarifications or corrections. Addenda will become part of the contract documents when the contract is executed.

   E. Contract Drawings: Drawings of the work to be done as listed hereafter in Section 00850 Drawing Schedule and/or Section 00870 Plans and Details.

   F. Utility: WE Energies.

   G. End User: City of Milwaukee.

4. Control of Work and Materials:

   A. Detail and Shop Drawings: Shop drawings and other additional drawings which may be required for each contract of the work shall be prepared by each respective contractor unless

otherwise directed by the Facilities Manager. Prints shall be the same size as contract documents when practical. Prints of each drawing shall be submitted to the Facilities Manager for approval before proceeding with the work. Changes ordered by the Facilities Manager shall be made and revised prints submitted as above. The Facilities Manager's approval of drawings shall not relieve the contractor of responsibility for errors.

B. Primary Lines and Grades: The City of Milwaukee will mark two building corners along a line and will establish a benchmark, with a relative elevation, within close proximity to the site. Once established by the City, the contractor shall preserve all points and benchmark as long as needed during construction. The contractor will bear all costs associated with re-establishing points and benchmark.

C. Construction Lines and Grades: The contractor must bear sole responsibility for the correct transfer of all construction lines and grades from the primary lines and grades points. He shall take such measurements from existing work as may be necessary to insure the proper construction of his work.

D. Material Orders and Shipping Statements: The contractor shall furnish to the Facilities Manager at least two (2) copies of all material orders and shipping statements. Itemized weights of the materials and individual units of finished work shall be shown.

E. Weighing of Materials and Fabricated Units: The weighing of materials and fabricated units such as structural steel, casings, etc., when required, shall be done in the presence of the Commissioner's representative. The contractor shall be responsible for the satisfactory weighing of such materials and units.

F. Consignment and Delivery of Materials: The materials for the work shall be consigned to the contractor and he shall be responsible for the delivery of all materials required for the completion of the contract.

5. Samples and Tests:

A. Method of Sampling: Samples of the materials proposed or furnished for the work may be taken by the Commissioner at any time; at the point of manufacture, point of delivery or site of work. They will be selected, as far as practicable, in accordance with standard methods of sampling such materials as specified in the standard of the American Society for Testing Material. All sampling shall be done by authorized representatives of the Commissioner. Selections will be in an orderly and systematic manner, insuring samples representative of the lot.

B. A.S.T.M. Standards: Wherever the abbreviation A.S.T.M. is used in connection with the number of a standard specification, the specification referred to shall be the Standard of the American Society for Testing Materials, designated by that number, including all revisions in effect on the date of award of the contract. Should a revised or amended standard be issued by the American Society for Testing Materials which, in the opinion of the Commissioner, conflicts with or causes undesirable changes in the standards referred to herein, the Commissioner reserves the right, by means of addenda to the project manual, to continue under the provisions of the pertinent standard referred to herein.

C. Cost of Test Specimens and Samples: All test specimens of metals and all samples of non-metals required for tests shall be furnished by the contractor without cost to the City.

D. Costs of Tests: All tests on test specimens of metals will be made at the expense of the

contractor and the original test on samples of non-metals will be made at the expense of the City. In all cases, the testing procedure will be in accordance with Standard A.S.T.M. tests for such materials. Subsequent tests of non-metals requested by the contractor, when such tests are permitted by A.S.T.M. Specifications and approved by the Commissioner or subsequent tests ordered by the Commissioner will be made at the expense of the contractor.

6. Project Coordination:

A. Contractors are required, so far as possible; to arrange work and to dispose of materials so as not to interfere with the work or storage of materials of other contractors or City forces engaged upon the work.

B. Contractors shall give full cooperation to other trades and furnish any information necessary to permit the work of all trades to be installed satisfactorily and with the least possible interference or delay.

C. Where the work of a contractor will be installed in close proximity to the work of other trades, or where there is evidence that the work of a contractor will interfere with the work of other trades, he shall assist in working out space conditions to make satisfactory adjustments.

D. If a contractor installs work before coordinating it with other trades or so as to cause interference with work of other trades, he shall make necessary changes in his work to correct the condition without extra charge.

E. Contractors are required to join their work to that of others in a proper manner, and in accordance with the spirit of the plans and project manual, and to perform the work in the proper sequence in relation to that of other contractors, and as may be directed by the Project Inspector.

7. Supervision of Work:

A. Contractors shall furnish the services of an experienced engineer or superintendent.

B. He shall be constantly in charge of the installation of the work together with all subcontractors, skilled workers, helpers, and labor required to unload, transfer, erect, connect up, adjust, start, operate and test each system.

C. He shall be thoroughly acquainted with and be responsible for the various subcontractors' work so that it is properly coordinated and supervised to the satisfaction of the Commissioner of Public Works or his representative.

D. Upon written notice to a contractor of the lack of such coordination and supervision, the Commissioner of Public Works may authorize such services as may be required and deduct the cost of this service at an hourly rate of $60.00 per hour per worker from the contract for the work.

8. Technical Specifications and Drawings:

A. Governing order of Contract Documents:

1. The following provision modifies DPW General Specifications Item 2.1.3.1:

Anything mentioned in the Technical Specifications and not shown on the drawings or shown on the drawings and not mentioned in the Technical Specifications, shall be as if

shown on or mentioned in both. In case of difference between drawings and Technical Specifications, the Technical Specifications shall govern. In case of any discrepancy in drawings or Technical Specifications, the matter shall be immediately submitted to FACILITIES DEVELOPMENT AND MANAGEMENT SECTION for decision. Said discrepancy shall not be adjusted by the contractor.

B. All contractors shall have complete sets of plans and project manuals on the job site at all times.

9. Safety Regulations:

All work shall be done in accordance with the safety requirements referenced in the International Building Code, as adopted and amended by the State of Wisconsin and OSHA standards.

10. Code Rules:

The rulings, regulations and laws of the following shall be complied with in the completion of this project:

International Building Code, as amended and adopted by the State of Wisconsin
Plumbing and Drainage Codes of the City of Milwaukee
Ordinances of the City of Milwaukee
National Board of Fire Underwriters
OSHA
NFPA
FAA
NEC
IEEE
UL

Rev. 3/04

SECTION 00821: INSPECTION CHARGES

The contractor will be charged a fee for inspection for each and every day such inspection is required after the time allowed for completion has expired.

The amount of the fee for inspection shall be $325.00 per day.

The time allowed for completion is stated in the Specific Official Notice and shall start with the date on the Notice to Proceed which will be sent to the contractor directly following the signing of the contract. The time allowed includes the time required for fabricating and procuring material and doing the work at the building site.

PREVAILING WAGE RATE DETERMINATION
Issued by the State of Wisconsin
Department of Workforce Development
Pursuant to s. 66.0903, Wis. Stats.
Issued On: 01/13/2012
Amended On: 03/02/2012

DETERMINATION NUMBER: 201200107

EXPIRATION DATE: Prime Contracts MUST Be Awarded or Negotiated On Or Before 12/31/2012. If NOT, You MUST Reapply.

PROJECT NAME: ALL PUBLIC WORKS PROJECTS UNDER SEC. 66.0903, STATS.-CITY OF MILWAUKEE

PROJECT LOCATION: MILWAUKEE CITY, MILWAUKEE COUNTY, WI

CONTRACTING AGENCY: CITY OF MILWAUKEE-DEPT OF PUBLIC WORKS

CLASSIFICATION:	Contractors are responsible for correctly classifying their workers. Either call the Department of Workforce Development (DWD) with trade or classification questions or consult DWD's Dictionary of Occupational Classifications & Work Descriptions on the DWD website at: dwd.wisconsin.gov/er/prevailing_wage_rate/Dictionary/dictionary_main.htm.
OVERTIME:	Time and one-half must be paid for all hours worked: - over 10 hours per day on prevailing wage projects - over 40 hours per calendar week - Saturday and Sunday - on all of the following holidays: January 1; the last Monday in May; July 4; the 1st Monday in September; the 4th Thursday in November; December 25; - The day before if January 1, July 4 or December 25 falls on a Saturday; - The day following if January 1, July 4 or December 25 falls on a Sunday. Apply the time and one-half overtime calculation to whichever is higher between the Hourly Basic Rate listed on this project determination or the employee's regular hourly rate of pay. Add any applicable Premium or DOT Premium to the Hourly Basic Rate before calculating overtime. A DOT Premium (discussed below) may supersede this time and one-half requirement.
FUTURE INCREASE:	When a specific trade or occupation requires a future increase, you MUST add the full hourly increase to the "TOTAL" on the effective date(s) indicated for the specific trade or occupation.
PREMIUM PAY:	If indicated for a specific trade or occupation, the full amount of such pay MUST be added to the "HOURLY BASIC RATE OF PAY" indicated for such trade or occupation, whevenever such pay is applicable.
DOT PREMIUM:	This premium only applies to highway and bridge projects owned by the Wisconsin Department of Transportation and to the project type heading "Airport Pavement or State Highway Construction." DO NOT apply the premium calculation under any other project type on this determination.
APPRENTICES:	Pay apprentices a percentage of the applicable journeyperson's hourly basic rate of pay and hourly fringe benefit contributions specified in this determination. Obtain the appropriate percentage from each apprentice's contract or indenture.
SUBJOURNEY:	Subjourney wage rates may be available for some of the trades or occupations indicated below with the exception of laborers, truck drivers and heavy equipment operators. Any employer interested in using a subjourney classification on this project MUST complete Form ERD-10880 and request the applicable wage rate from the Department of Workforce Development PRIOR to using the subjourney worker on this project.

This document **MUST BE POSTED** by the **CONTRACTING AGENCY** in at least one conspicuous and easily accessible place **on the site of the project** . A local governmental unit may post this document at the place normally used to post public notices if there is no common site on the project. This document **MUST** remain posted during the entire time any worker is employed on the project and **MUST** be physically incorporated into the specifications and all contracts and subcontracts. If you have any questions, please write to the Equal Rights Division, Labor Standards Bureau, P.O. Box 8928, Madison, Wisconsin 53708 or call (608) 266-6861.

The following statutory provisions apply to local governmental unit projects of public works and are set forth below pursuant to the requirements of s. 66.0903(8), Stats.

s. 66.0903 (1) (f) & s. 103.49 (1) (c) "PREVAILING HOURS OF LABOR" for any trade or occupation in any area means 10 hours per day and 40 hours per week and may not include any hours worked on a Saturday or Sunday or on any of the following holidays:

1. January 1.
2. The last Monday in May.
3. July 4.
4. The first Monday in September.
5. The 4th Thursday in November.
6. December 25.
7. The day before if January 1, July 4 or December 25 falls on a Saturday.
8. The day following if January 1, July 4 or December 25 falls on a Sunday.

s. 66.0903 (10) RECORDS; INSPECTION; ENFORCEMENT.
(a) Each contractor, subcontractor, or contractor's or subcontractor's agent performing work on a project of public works that is subject to this section shall keep full and accurate records clearly indicating the name and trade or occupation of every person performing the work described in sub. (4) and an accurate record of the number of hours worked by each of those persons and the actual wages paid for the hours worked.

s. 66.0903 (11) LIABILITY AND PENALTIES.
(a) 1. Any contractor, subcontractor, or contractor's or subcontractor's agent who fails to pay the prevailing wage rate determined by the department under sub. (3) or who pays less than 1.5 times the hourly basic rate of pay for all hours worked in excess of the prevailing hours of labor is liable to any affected employee in the amount of his or her unpaid wages or his or her unpaid overtime compensation and in an additional amount as liquidated damages as provided under subd. 2., 3., whichever is applicable.
2. If the department determines upon inspection under sub. (10) (b) or (c) that a contractor, subcontractor, or contractor's or subcontractor's agent has failed to pay the prevailing wage rate determined by the department under sub. (3) or has paid less than 1.5 times the hourly basic rate of pay for all hours worked in excess of the prevailing hours of labor, the department shall order the contractor to pay to any affected employee the amount of his or her unpaid wages or his or her unpaid overtime compensation and an additional amount equal to 100 percent of the amount of those unpaid wages or that unpaid overtime compensation as liquidated damages within a period specified by the department in the order.
3. In addition to or in lieu of recovering the liability specified in subd. 1. as provided in subd. 2., any employee for and in behalf of that employee and other employees similarly situated may commence an action to recover that liability in any court of competent jurisdiction. If the court finds that a contractor, subcontractor, or contractor's or subcontractor's agent has failed to pay the prevailing wage rate determined by the department under sub. (3) or has paid less than 1.5 times the hourly basic rate of pay for all hours worked in excess of the prevailing hours of labor, the court shall order the contractor, subcontractor, or agent to pay to any affected employee the amount of his or her unpaid wages or his or her unpaid overtime compensation and an additional amount equal to 100 percent of the amount of those unpaid wages or that unpaid overtime compensation as liquidated damages.
5. No employee may be a party plaintiff to an action under subd. 3. unless the employee consents in writing to become a party and the consent is filed in the court in which the action is brought. Notwithstanding s. 814.04 (1), the court shall, in addition to any judgment awarded to the plaintiff, allow reasonable attorney fees and costs to be paid by the defendant.

BUILDING OR HEAVY CONSTRUCTION

Includes sheltered enclosures with walk-in access for the purpose of housing persons, employees, machinery, equipment or supplies and non-sheltered work such as canals, dams, dikes, reservoirs, storage tanks, etc. A sheltered enclosure need not be "habitable" in order to be considered a building. The installation of machinery and/or equipment, both above and below grade level, does not change a project's character as a building. On-site grading, utility work and landscaping are included within this definition. Residential buildings of four (4) stories or less, agricultural buildings, parking lots and driveways are NOT included within this definition.

SKILLED TRADES

Fringe Benefits Must Be Paid On All Hours Worked

CODE	TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
101	Acoustic Ceiling Tile Installer	33.43	19.31	52.74
102	Boilermaker	31.09	21.87	52.96
103	Bricklayer, Blocklayer or Stonemason Future Increase(s): Add $.50 on 6/01/2012; Add $1.45/hr on 6/01/2013 Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	35.58	16.37	51.95
104	Cabinet Installer	29.06	15.16	44.22
105	Carpenter Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	33.43	19.31	52.74
106	Carpet Layer or Soft Floor Coverer	31.68	18.55	50.23
107	Cement Finisher	30.87	16.33	47.20
108	Drywall Taper or Finisher Future Increase(s): Add $2.20/hr on 6/1/2012	28.97	17.74	46.71
109	Electrician Future Increase(s): Add $1.40/hr on 6/1/2012. Add $1.60/hr on 6/1/2013. Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	31.54	20.95	52.49
110	Elevator Constructor	43.79	25.48	69.27
111	Fence Erector	27.00	0.00	27.00
112	Fire Sprinkler Fitter	36.82	19.03	55.85
113	Glazier	32.25	16.20	48.45
114	Heat or Frost Insulator	33.28	22.45	55.73

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
115	Insulator (Batt or Blown)	23.62	11.55	35.17
116	Ironworker	31.31	21.54	52.85
117	Lather	31.68	18.41	50.09
118	Line Constructor (Electrical)	35.97	18.08	54.05
119	Marble Finisher	31.16	16.27	47.43
120	Marble Mason	35.53	15.92	51.45
121	Metal Building Erector	21.05	7.82	28.87
122	Millwright	28.30	23.29	51.59
123	Overhead Door Installer	26.53	0.00	26.53
124	Painter Future Increase(s): Add $2.20/hr on 6/1/2012. Premium Increase(s): Add $.20/hr for paperhanging; Add $.35/hr for bridge, iron and drywall; Add $.75/hr for spraying and sandblasting; Add $.60/hr for EIFS work; Add $1.00/hr for lead based paint removal.	28.97	17.74	46.71
125	Pavement Marking Operator	26.00	0.00	26.00
126	Piledriver	28.11	23.94	52.05
127	Pipeline Fuser or Welder (Gas or Utility)	30.52	18.84	49.36
129	Plasterer	20.13	1.03	21.16
130	Plumber	36.97	17.47	54.44
132	Refrigeration Mechanic	37.21	19.04	56.25
133	Roofer or Waterproofer Future Increase(s): Add $.50/hr. effective 06/01/2012	29.40	15.05	44.45
134	Sheet Metal Worker	37.20	16.37	53.57
135	Steamfitter	38.26	19.49	57.75
137	Teledata Technician or Installer Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year’s Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	24.65	15.67	40.32
138	Temperature Control Installer	29.63	19.17	48.80
139	Terrazzo Finisher	18.00	5.35	23.35
140	Terrazzo Mechanic	31.16	16.27	47.43

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
141	Tile Finisher	23.76	16.05	39.81
142	Tile Setter	29.95	15.64	45.59
143	Tuckpointer, Caulker or Cleaner Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	34.35	15.92	50.27
144	Underwater Diver (Except on Great Lakes)	36.20	18.81	55.01
146	Well Driller or Pump Installer	25.32	15.30	40.62
147	Siding Installer	36.60	16.37	52.97
150	Heavy Equipment Operator - ELECTRICAL LINE CONSTRUCTION ONLY	27.42	15.10	42.52
151	Light Equipment Operator -ELECTRICAL LINE CONSTRUCTION ONLY	28.78	15.16	43.94
152	Heavy Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	17.80	9.00	26.80
153	Light Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	23.38	12.48	35.86
154	Groundman - ELECTRICAL LINE CONSTRUCTION ONLY	21.30	10.97	32.27

TRUCK DRIVERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
201	Single Axle or Two Axle	32.32	16.75	49.07
203	Three or More Axle Future Increase(s): Add $1.75/hr on 6/1/2012; Add $1.85/hr on 6/1/2013. Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	22.50	16.19	38.69
204	Articulated, Euclid, Dumptor, Off Road Material Hauler	33.32	17.60	50.92
205	Pavement Marking Vehicle	19.25	10.84	30.09
207	Truck Mechanic	24.91	15.35	40.26

LABORERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
301	General Laborer Premium Increase(s): Add $.11 for mortar mixer, fork lift operator, air and electric equipment and power buggy operators; Add $.22 for jackhammer operator, certified welder, gunite machineman.	28.82	15.61	44.43
302	Asbestos Abatement Worker	21.58	17.83	39.41
303	Landscaper	12.50	2.20	14.70
310	Gas or Utility Pipeline Laborer (Other Than Sewer and Water)	19.14	15.53	34.67
311	Fiber Optic Laborer (Outside, Other Than Concrete Encased) Premium Increase(s): DOT PREMIUMS: Pay two times the hourly basic rate on New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	17.24	15.00	32.24
314	Railroad Track Laborer	17.00	1.06	18.06

HEAVY EQUIPMENT OPERATORS
SITE PREPARATION, UTILITY OR LANDSCAPING WORK ONLY

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
501	Air Track, Rotary or Percussion Drilling Machine &/or Hammers, Blaster; Asphalt Milling Machine; Boring Machine (Directional, Horizontal or Vertical); Backhoe (Track Type) Having a Mfgr's Rated Capacity of 130,000 Lbs. or Over; Backhoe (Track Type) Having a Mfgr's Rated Capacity of Under 130,000 Lbs., Backhoe (Mini, 15,000 Lbs. & Under); Bulldozer or Endloader (Over 40 hp); Compactor (Self-Propelled 85 Ft Total Drum Width & Over, or Tractor Mounted, Towed & Light Equipment); Concrete Batch Plant, Batch Hopper; Concrete Breaker (Large, Auto, Vibratory/Sonic, Manual or Remote); Crane, Shovel, Dragline, Clamshells; Forklift (Machinery Moving or Steel Erection, 25 Ft & Over); Gradall (Cruz-Aire Type); Grader or Motor Patrol; Master Mechanic; Mechanic or Welder; Robotic Tool Carrier (With or Without Attachments); Scraper (Self Propelled or Tractor Drawn) 5 cu yds or More Capacity; Tractor or Truck Mounted Hydraulic Backhoe; Tractor or Truck Mounted Hydraulic Crane (10 Tons or Under); Tractor (Scraper, Dozer, Pusher, Loader); Trencher (Wheel Type or Chain Type Having Over 8 Inch Bucket).	32.32	18.18	50.50
502	Backfiller; Broom or Sweeper; Bulldozer or Endloader (Under 40 hp); Environmental Burner; Forestry Equipment, Timbco, Tree Shear, Tub Grinder, Processor; Jeep Digger; Screed (Milling Machine); Skid Rig; Straddle Carrier or Travel Lift; Stump Chipper; Trencher (Wheel Type or Chain Type Having 8 Inch Bucket & Under).	33.32	17.60	50.92

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
503	Air Compressor (&/or 400 CFM or Over); Augers (Vertical & Horizontal); Compactor (Self-Propelled 84 Ft Total Drum Width & Under, or Tractor Mounted, Towed & Light Equipment); Crusher, Screening or Wash Plant; Farm or Industrial Type Tractor; Forklift; Generator (&/or 150 KW or Over); Greaser; High Pressure Utility Locating Machine (Daylighting Machine); Mulcher; Oiler; Post Hole Digger or Driver; Pump (3 Inch or Over) or Well Points; Refrigeration Plant or Freeze Machine; Rock, Stone Breaker; Skid Steer Loader (With or Without Attachments); Vibratory Hammer or Extractor, Power Pack.	32.32	17.59	49.91
504	Work Performed on the Great Lakes Including Diver; Wet Tender or Hydraulic Dredge Engineer.	36.20	18.81	55.01
505	Work Performed on the Great Lakes Including Crane or Backhoe Operator; Assistant Hydraulic Dredge Engineer; Hydraulic Dredge Leverman or Diver's Tender; Mechanic or Welder; 70 Ton & Over Tug Operator. Premium Increase(s): Add $.50/hr for friction crane, lattice boom or crane certification (CCO).	37.45	19.45	56.90
506	Work Performed on the Great Lakes Including Deck Equipment Operator or Machineryman (Maintains Cranes Over 50 Tons or Backhoes 115,000 Lbs. or More); Tug, Launch or Loader, Dozer or Like Equipment When Operated on a Barge, Breakwater Wall, Slip, Dock or Scow, Deck Machinery.	26.80	18.52	45.32
507	Work Performed on the Great Lakes Including Deck Equipment Operator, Machineryman or Fireman (Operates 4 Units or More or Maintains Cranes 50 Tons or Under or Backhoes 115,000 Lbs. or Under); Deck Hand, Deck Engineer or Assistant Tug Operator; Off Road Trucks - Great Lakes ONLY.	27.75	19.15	46.90

HEAVY EQUIPMENT OPERATORS
EXCLUDING SITE PREPARATION, UTILITY, PAVING LANDSCAPING WORK

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
508	Boring Machine (Directional); Crane, Tower Crane, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of Over 100 Tons, Self-Erecting Tower Crane With a Lifting Capacity of Over 4,000 Lbs., Crane With Boom Dollies; Crane, Tower Crane, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 176 Ft or Over; Master Mechanic. Premium Increase(s): Crane Operators with CCO certification add $.50/hr. Cranes with boom length over 200 ft. not exceeding 300 ft. OR lifting capacity over 200 ton not exceeding 300 ton add $.50/hr. Over 300 ton OR 300 ft. add $.01/hr. per foot OR ton whichever is greater.	39.16	19.10	58.26

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
509	Backhoe (Track Type) Having a Mfgr's Rated Capacity of 130,000 Lbs. or Over; Boring Machine (Horizontal or Vertical); Caisson Rig; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of 100 Tons or Under, Self-Erecting Tower Crane With A Lifting Capacity Of 4,000 Lbs. & Under; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 175 Ft or Under; Pile Driver; Versi Lifts, Tri-Lifts & Gantrys (20,000 Lbs. & Over). Premium Increase(s): Crane Operators with CCO certification add $.50/hr.	38.66	19.10	57.76
510	Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of Under 130,000 Lbs., Backhoe (Mini, 15,000 Lbs. & Under); Concrete Bump Cutter, Grinder, Planing or Grooving Machine; Concrete Laser/Screed; Concrete Paver (Slipform); Concrete Pump (Over 46 Meter), Concrete Conveyor (Rotec or Bidwell Type); Concrete Slipform Placer Curb & Gutter Machine; Concrete Spreader & Distributor; Dredge (NOT Performing Work on the Great Lakes); Forklift (Machinery Moving or Steel Erection, 25 Ft & Over); Gradall (Cruz-Aire Type); Hydro-Blaster (10,000 PSI or Over); Milling Machine; Skid Rig; Traveling Crane (Bridge Type). Premium Increase(s): Crane Operators with CCO certification add $.50/hr.	38.16	19.10	57.26
511	Air, Track, Rotary or Percussion Drilling Machine &/or Hammers, Blaster; Bulldozer or Endloader (Over 40 hp); Compactor (Self-Propelled 85 Ft Total Drum Width & Over, or Tractor Mounted, Towed & Light Equipment); Concrete Pump (46 Meter & Under), Concrete Conveyor (Rotec or Bidwell Type); Crane (Carry Deck, Mini) or Truck Mounted Hydraulic Crane (10 Tons or Under); Environmental Burner; Gantrys (Under 20,000 Lbs.); Grader or Motor Patrol; High Pressure Utility Locating Machine (Daylighting Machine); Manhoist; Material or Stack Hoist; Mechanic or Welder; Railroad Track Rail Leveling Machine, Tie Placer, Extractor, Tamper, Stone Leveler or Rehabilitation Equipment; Roller (Over 5 Ton); Scraper (Self Propelled or Tractor Drawn) 5 cu yd or More Capacity; Screed (Milling Machine); Sideboom; Straddle Carrier or Travel Lift; Tining or Curing Machine; Tractor (Scraper, Dozer, Pusher, Loader); Tractor or Truck Mounted Hydraulic Backhoe; Tractor or Truck Mounted Hydraulic Crane (10 Tons or Under); Trencher (Wheel Type or Chain Type Having Over 8-Inch Bucket). Premium Increase(s): Crane Operators with CCO certification add $.50/hr.	38.16	19.10	57.26
512	Backfiller; Broom or Sweeper; Bulldozer or Endloader (Under 40 hp); Compactor (Self-Propelled 84 Ft Total Drum Width & Under, or Tractor Mounted, Towed & Light Equipment); Concrete Batch Plant, Batch Hopper; Concrete Breaker (Large, Auto, Vibratory/Sonic, Manual or Remote); Concrete Conveyor System; Concrete Finishing Machine (Road Type); Fireman (Pile Driver & Derrick NOT Performing Work on the Great Lakes); Grout Pump; Hoist (Tugger, Automatic); Industrial Locomotives; Jeep Digger; Lift Slab Machine; Mulcher; Robotic Tool Carrier (With or Without Attachments); Roller (Rubber Tire, 5 Ton or Under); Screw or Gypsum Pumps; Stabilizing or Concrete Mixer (Self-Propelled or 14S or Over); Stump Chipper; Trencher (Wheel Type or Chain Type Having 8-Inch Bucket & Under); Winches & A-Frames.	37.47	19.10	56.57

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
513	Air Compressor (&/or 400 CFM or Over); Air, Electric or Hydraulic Jacking System; Augers (Vertical & Horizontal); Boatmen (NOT Performing Work on the Great Lakes); Boiler (Temporary Heat); Crusher, Screening or Wash Plant; Elevator; Farm or Industrial Type Tractor; Fireman (Asphalt Plant NOT Performing Work on the Great Lakes); Forklift; Generator (&/or 150 KW or Over); Greaser; Heaters (Mechanical); Loading Machine (Conveyor); Oiler; Post Hole Digger or Driver; Prestress Machine; Pump (3 Inch or Over) or Well Points; Refrigeration Plant or Freeze Machine; Rock, Stone Breaker; Skid Steer Loader (With or Without Attachments); Vibratory Hammer or Extractor, Power Pack.	30.44	19.10	49.54
514	Gas or Utility Pipeline, Except Sewer & Water (Primary Equipment). Future Increase(s): Add $2/hr. on 1/1/2013.	34.89	19.68	54.57
515	Gas or Utility Pipeline, Except Sewer & Water (Secondary Equipment).	31.26	17.40	48.66
516	Fiber Optic Cable Equipment	25.74	15.85	41.59

SEWER, WATER OR TUNNEL CONSTRUCTION

Includes those projects that primarily involve public sewer or water distribution, transmission or collection systems and related tunnel work (excluding buildings).

SKILLED TRADES

Fringe Benefits Must Be Paid On All Hours Worked

CODE	TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
103	Bricklayer, Blocklayer or Stonemason	35.53	15.92	51.45
105	Carpenter Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	33.43	19.31	52.74
107	Cement Finisher Future Increase(s): Add $1.86 on 6/1/12; Add $1.87 on 6/1/13; Add $1.87 on 6/1/14; Add $1.87 on 6/1/15; Add $1.75 on 6/1/16. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.40/hr when the Wisconsin Department of Transportation or responsible governing agency requires that work be performed at night under artificial illumination with traffic control and the work is completed after sunset and before sunrise.	27.14	19.22	46.36
109	Electrician Future Increase(s): Add $1.40/hr on 6/1/2012. Add $1.60/hr on 6/1/2013. Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year’s Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	31.54	20.95	52.49
111	Fence Erector	27.00	0.00	27.00
116	Ironworker Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	31.31	22.22	53.53
118	Line Constructor (Electrical)	35.97	18.08	54.05
125	Pavement Marking Operator	26.00	0.00	26.00
126	Piledriver	28.11	23.94	52.05
130	Plumber	36.18	16.86	53.04
135	Steamfitter	35.81	19.04	54.85
137	Teledata Technician or Installer	24.65	15.17	39.82

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
143	Tuckpointer, Caulker or Cleaner	34.30	15.47	49.77
144	Underwater Diver (Except on Great Lakes)	36.20	18.81	55.01
146	Well Driller or Pump Installer	24.22	14.80	39.02
150	Heavy Equipment Operator - ELECTRICAL LINE CONSTRUCTION ONLY	27.42	15.10	42.52
151	Light Equipment Operator -ELECTRICAL LINE CONSTRUCTION ONLY	28.78	15.16	43.94
152	Heavy Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	17.80	9.00	26.80
153	Light Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	23.38	12.48	35.86
154	Groundman - ELECTRICAL LINE CONSTRUCTION ONLY	21.30	10.97	32.27

TRUCK DRIVERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
201	Single Axle or Two Axle	23.00	8.64	31.64
203	Three or More Axle	17.54	13.41	30.95
204	Articulated, Euclid, Dumptor, Off Road Material Hauler Future Increase(s): Add $1.75/hr on 6/1/2012; Add $1.85/hr on 6/1/2013. Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	22.50	16.19	38.69
205	Pavement Marking Vehicle	19.25	10.84	30.09
207	Truck Mechanic	17.54	13.41	30.95

LABORERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
301	General Laborer Future Increase(s): Add $1.73/hr on 6/4/2012. Premium Increase(s): Add $1.92 for bottomman; Add $2.03 for concrete manhole builder, bracer, jointman, or pipelayer; Add $4.83 for blaster. Add $2.00 for all tunnel work under 15 lbs. compressed air; Add $2.00 for 0-30 lbs. compressed air; Add $3.00 for over 30 lbs. compressed air.	27.72	15.61	43.33

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
303	Landscaper	12.50	2.20	14.70
304	Flagperson or Traffic Control Person	22.50	12.90	35.40
311	Fiber Optic Laborer (Outside, Other Than Concrete Encased)	17.09	14.40	31.49
314	Railroad Track Laborer	17.00	1.06	18.06

HEAVY EQUIPMENT OPERATORS
SEWER, WATER OR TUNNEL WORK

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
521	Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of 130,000 Lbs. or Over; Caisson Rig; Crane, Tower Crane, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 176 Ft or Over; Crane, Tower Crane, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of Over 100 Tons, Self-Erecting Tower Crane With a Lifting Capacity Of Over 4,000 Lbs., Crane With Boom Dollies; Master Mechanic; Pile Driver. Premium Increase(s): Crane Operators with CCO certification add $.50/hr. Cranes with boom length over 200 ft. not exceeding 300 ft. OR lifting capacity over 200 ton not exceeding 300 ton add $.50/hr. Over 300 ton OR 300 ft. add $.01/hr. per foot OR ton whichever is greater.	39.16	19.10	58.26
522	Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of Under 130,000 Lbs., Backhoe (Mini, 15,000 Lbs. & Under); Boring Machine (Directional); Concrete Bump Cutter, Grinder, Planing or Grooving Machine; Concrete Laser/Screed; Concrete Paver (Slipform); Concrete Pump (Over 46 Meter), Concrete Conveyor (Rotec or Bidwell Type); Concrete Spreader & Distributor; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 175 Ft or Under; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of 100 Tons or Under, Self-Erecting Tower Crane With a Lifting Capacity of 4,000 Lbs. & Under; Dredge (NOT Performing Work on the Great Lakes); Milling Machine; Skid Rig; Telehandler; Traveling Crane (Bridge Type). Future Increase(s): Add $2.05/hr on 6/4/2012. Premium Increase(s): Add $.25/hr for operating tower crane.	33.91	18.55	52.46

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
523	Air Track, Rotary or Percussion Drilling Machine &/or Hammers, Blaster; Boring Machine (Horizontal or Vertical); Bulldozer or Endloader (Over 40 hp); Crane (Carry Deck, Mini) or Truck Mounted Hydraulic Crane (10 Tons or Under); Concrete Pump (46 Meter & Under), Concrete Conveyor (Rotec or Bidwell Type); Concrete Slipform Placer Curb & Gutter Machine; Gradall (Cruz-Aire Type); Grader or Motor Patrol; Hydro-Blaster (10,000 PSI or Over); Manhoist; Material or Stack Hoist; Mechanic or Welder; Roller (Over 5 Ton); Scraper (Self Propelled or Tractor Drawn) 5 cu yd or More Capacity; Screed (Milling Machine); Sideboom; Straddle Carrier or Travel Lift; Tractor (Scraper, Dozer, Pusher, Loader); Tractor or Truck Mounted Hydraulic Backhoe; Tractor or Truck Mounted Hydraulic Crane (10 Tons or Under); Trencher (Wheel Type or Chain Type Having Over 8-Inch Bucket). Future Increase(s): Add $2.05/hr on 6/4/2012. Premium Increase(s): Add $.25/hr for operating tower crane.	32.96	18.55	51.51
524	Backfiller; Broom or Sweeper; Bulldozer or Endloader (Under 40 hp); Compactor (Self-Propelled 85 Ft Total Drum Width & Over, or Tractor Mounted, Towed & Light Equipment); Concrete Batch Plant, Batch Hopper; Concrete Breaker (Large, Auto, Vibratory/Sonic, Manual or Remote); Concrete Conveyor System; Concrete Finishing Machine (Road Type); Environmental Burner; Fireman (Pile Driver & Derrick NOT Performing Work on the Great Lakes); Forestry Equipment, Timbco, Tree Shear, Tub Grinder, Processor; Hoist (Tugger, Automatic); Grout Pump; Jeep Digger; Lift Slab Machine; Mulcher; Power Subgrader; Pump (3 Inch or Over) or Well Points; Robotic Tool Carrier (With or Without Attachments); Roller (Rubber Tire, 5 Ton or Under); Screw or Gypsum Pumps; Stabilizing or Concrete Mixer (Self-Propelled or 14S or Over); Stump Chipper; Tining or Curing Machine; Trencher (Wheel Type or Chain Type Having 8-Inch Bucket & Under); Winches & A-Frames.	30.89	18.12	49.01
525	Air Compressor (&/or 400 CFM or Over); Air, Electric or Hydraulic Jacking System; Augers (Vertical & Horizontal); Compactor (Self-Propelled 84 Ft Total Drum Width & Under, or Tractor Mounted, Towed & Light Equipment); Crusher, Screening or Wash Plant; Farm or Industrial Type Tractor; Fireman (Asphalt Plant NOT Performing Work on the Great Lakes); Generator (&/or 150 KW or Over); Heaters (Mechanical); High Pressure Utility Locating Machine (Daylighting Machine); Loading Machine (Conveyor); Post Hole Digger or Driver; Refrigeration Plant or Freeze Machine; Rock, Stone Breaker; Skid Steer Loader (With or Without Attachments); Vibratory Hammer or Extractor, Power Pack. Future Increase(s): Add $2.05/hr on 6/4/2012. Premium Increase(s): Add $.25/hr for operating tower crane.	30.51	18.55	49.06
526	Boiler (Temporary Heat); Forklift; Greaser; Oiler.	29.44	18.10	47.54
527	Work Performed on the Great Lakes Including Diver; Wet Tender or Hydraulic Dredge Engineer.	36.20	18.81	55.01

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
528	Work Performed on the Great Lakes Including 70 Ton & Over Tug Operator; Assistant Hydraulic Dredge Engineer; Crane or Backhoe Operator; Hydraulic Dredge Leverman or Diver's Tender; Mechanic or Welder.	36.20	18.81	55.01
529	Work Performed on the Great Lakes Including Deck Equipment Operator or Machineryman (Maintains Cranes Over 50 Tons or Backhoes 115,000 Lbs. or More); Tug, Launch or Loader, Dozer or Like Equipment When Operated on a Barge, Breakwater Wall, Slip, Dock or Scow, Deck Machinery.	26.80	18.52	45.32
530	Work Performed on the Great Lakes Including Deck Equipment Operator; Machineryman or Fireman (Operates 4 Units or More or Maintains Cranes 50 Tons or Under or Backhoes 115,000 Lbs. or Under), Deck Hand, Deck Engineer or Assistant Tug Operator; Off Road Trucks - Great Lakes ONLY.	26.80	18.52	45.32

AIRPORT PAVEMENT OR STATE HIGHWAY CONSTRUCTION

Includes all airport projects (excluding buildings) and all projects awarded by the Wisconsin Department of Transportation (excluding buildings).

SKILLED TRADES

Fringe Benefits Must Be Paid On All Hours Worked

CODE	TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
103	Bricklayer, Blocklayer or Stonemason	32.66	15.92	48.58
105	Carpenter Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	33.43	19.31	52.74
107	Cement Finisher Future Increase(s): Add $1.86 on 6/1/12; Add $1.87 on 6/1/13; Add $1.87 on 6/1/14; Add $1.87 on 6/1/15; Add $1.75 on 6/1/16. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.40/hr when the Wisconsin Department of Transportation or responsible governing agency requires that work be performed at night under artificial illumination with traffic control and the work is completed after sunset and before sunrise.	29.33	17.03	46.36
109	Electrician	31.64	23.78	55.42
111	Fence Erector	35.62	0.00	35.62
116	Ironworker	31.31	21.54	52.85
118	Line Constructor (Electrical)	35.97	18.08	54.05
124	Painter	27.87	14.39	42.26
125	Pavement Marking Operator	27.87	14.39	42.26
126	Piledriver Premium Increase(s): Add $.65/hr for Piledriver Loftsman; Add $.75/hr for Sheet Piling Loftsman. DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	29.56	24.96	54.52
133	Roofer or Waterproofer	28.85	14.60	43.45
137	Teledata Technician or Installer	24.65	15.17	39.82
143	Tuckpointer, Caulker or Cleaner	34.30	15.47	49.77
144	Underwater Diver (Except on Great Lakes)	36.20	18.81	55.01

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
150	Heavy Equipment Operator - ELECTRICAL LINE CONSTRUCTION ONLY	33.87	16.10	49.97
151	Light Equipment Operator -ELECTRICAL LINE CONSTRUCTION ONLY Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	29.64	14.64	44.28
152	Heavy Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	25.18	13.07	38.25
153	Light Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	23.38	12.48	35.86
154	Groundman - ELECTRICAL LINE CONSTRUCTION ONLY	21.30	10.97	32.27

TRUCK DRIVERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
201	Single Axle or Two Axle Future Increase(s): Add $1.75/hr on 6/1/2012; Add $1.85/hr on 6/1/2013. Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	22.35	16.19	38.54
203	Three or More Axle	24.91	15.63	40.54
204	Articulated, Euclid, Dumptor, Off Road Material Hauler Future Increase(s): Add $1.75/hr on 6/1/2012; Add $1.85/hr on 6/1/2013. Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	22.50	16.19	38.69
205	Pavement Marking Vehicle	23.84	14.70	38.54
206	Shadow or Pilot Vehicle	24.76	15.35	40.11
207	Truck Mechanic	24.91	15.63	40.54

LABORERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
301	General Laborer Future Increase(s): Add $1.60/hr on 6/1/2012: Add $1.70/hr on 6/1/2013; Add $1.60/hr on 6/1/2014. Premium Increase(s): Add $.15/hr for air tool operator, joint sawer and filler (pavement), vibrator or tamper operator (mechanical hand operated), chain saw operator and demolition burning torch laborer; Add $.35/hr for bituminous worker (raker and luteman), formsetter (curb, sidewalk and pavement) and strike off man; Add $.50/hr for line and grade specialist; Add $.65/hr for blaster and powderman; Add $2.01/hr for topman; Add $2.46/hr for bottomman; Add $3.23/hr for pipelayer. / DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	24.34	17.85	42.19
302	Asbestos Abatement Worker	22.00	16.86	38.86
303	Landscaper	23.71	15.03	38.74
304	Flagperson or Traffic Control Person Future Increase(s): Add $1.60/hr on 6/1/2012; Add $1.70/hr on 6/1/2013; Add $1.60/hr on 6/1/2014. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year’s Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr when the Wisconsin Department of Transportation or responsible governing agency requires that work be performed at night under artificial illumination with traffic control and the work is completed after sunset and before sunrise.	20.83	17.85	38.68
311	Fiber Optic Laborer (Outside, Other Than Concrete Encased)	17.09	14.40	31.49
314	Railroad Track Laborer	17.00	1.06	18.06

HEAVY EQUIPMENT OPERATORS
AIRPORT PAVEMENT OR STATE HIGHWAY CONSTRUCTION

Fringe Benefits Must Be Paid On All Hours Worked

CODE	TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
531	Crane, Tower Crane, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 176 Ft or Over; Crane, Tower Crane, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of Over 100 Tons, Self-Erecting Tower Crane With a Lifting Capacity Of Over 4,000 Lbs., Crane With Boom Dollies; Traveling Crane (Bridge Type). Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	34.22	18.90	53.12
532	Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of 130,000 Lbs. or Over; Caisson Rig; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 175 Ft or Under; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of 100 Tons or Under, Self-Erecting Tower Crane With A Lifting Capacity Of 4,000 Lbs., & Under; Dredge (NOT Performing Work on the Great Lakes); Licensed Boat Pilot (NOT Performing Work on the Great Lakes); Pile Driver. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	33.72	18.90	52.62

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
533	Air Track, Rotary or Percussion Drilling Machine &/or Hammers, Blaster; Asphalt Heater, Planer & Scarifier; Asphalt Milling Machine; Asphalt Screed; Automatic Subgrader (Concrete); Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of Under 130,000 Lbs., Backhoe (Mini, 15,000 Lbs. & Under); Bituminous (Asphalt) Plant & Paver, Screed; Boatmen (NOT Performing Work on the Great Lakes); Boring Machine (Directional, Horizontal or Vertical); Bridge (Bidwell) Paver; Bulldozer or Endloader; Concrete Batch Plant, Batch Hopper; Concrete Breaker (Large, Auto, VIbratory/Sonic, Manual or Remote); Concrete Bump Cutter, Grinder, Planing or Grooving Machine; Concrete Conveyor System; Concrete Laser/Screed; Concrete Paver (Slipform); Concrete Pump, Concrete Conveyor (Rotec or Bidwell Type); Concrete Slipform Placer Curb & Gutter Machine; Concrete Spreader & Distributor; Crane (Carry Deck, Mini) or Truck Mounted Hydraulic Crane (10 Tons or Under); Crane WIth a Lifting Capacity of 25 Tons or Under; Forestry Equipment, Timbco, Tree Shear, Tub Grinder, Processor; Gradall (Cruz-Aire Type); Grader or Motor Patrol; Grout Pump; Hydro-Blaster (10,000 PSI or Over); Loading Machine (Conveyor); Material or Stack Hoist; Mechanic or Welder; Milling Machine; Post Hole Digger or Driver; Roller (Over 5 Ton); Scraper (Self Propelled or Tractor Drawn) 5 cu yds or More Capacity; Shoulder Widener; Sideboom; Skid Rig; Stabilizing or Concrete Mixer (Self-Propelled or 14S or Over); Straddle Carrier or Travel Lift; Tractor (Scraper, Dozer, Pusher, Loader); Tractor or Truck Mounted Hydraulic Backhoe; Trencher (Wheel Type or Chain Type); Tube Finisher; Tugger (NOT Performing Work on the Great Lakes); Winches & A-Frames. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	33.22	18.90	52.12

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
534	Belting, Burlap, Texturing Machine; Broom or Sweeper; Compactor (Self-Propelled or Tractor Mounted, Towed & Light Equipment); Concrete Finishing Machine (Road Type); Environmental Burner; Farm or Industrial Type Tractor; Fireman (Asphalt Plant, Pile Driver & Derrick NOT Performing Work on the Great Lakes); Forklift; Greaser; Hoist (Tugger, Automatic); Jeep Digger; Joint Sawer (Multiple Blade); Launch (NOT Performing Work on the Great Lakes); Lift Slab Machine; Mechanical Float; Mulcher; Power Subgrader; Robotic Tool Carrier (With or Without Attachments); Roller (Rubber Tire, 5 Ton or Under); Self Propelled Chip Spreader; Shouldering Machine; Skid Steer Loader (With or WIthout Attachments); Telehandler; Tining or Curing Machine. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	32.96	18.90	51.86
535	Air Compressor (&/or 400 CFM or Over); Air, Electric or Hydraulic Jacking System; Augers (Vertical & Horizontal); Automatic Belt Conveyor & Surge Bin; Boiler (Temporary Heat); Concrete Proportioning Plant; Crusher, Screening or Wash Plant; Generator (&/or 150 KW or Over); Heaters (Mechanical); High Pressure Utility Locating Machine (Daylighting Machine); Mudjack; Oiler; Prestress Machine; Pug Mill; Pump (3 Inch or Over) or Well Points; Rock, Stone Breaker; Screed (Milling Machine); Stump Chipper; Tank Car Heaters; Vibratory Hammer or Extractor, Power Pack. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	32.67	18.90	51.57
536	Fiber Optic Cable Equipment.	24.39	15.45	39.84
537	Work Performed on the Great Lakes Including Diver; Wet Tender or Hydraulic Dredge Engineer.	36.20	18.81	55.01

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
538	Work Performed on the Great Lakes Including 70 Ton & Over Tug Operator; Assistant Hydraulic Dredge Engineer; Crane or Backhoe Operator; Hydraulic Dredge Leverman or Diver's Tender; Mechanic or Welder.	36.20	18.81	55.01
539	Work Performed on the Great Lakes Including Deck Equipment Operator or Machineryman (Maintains Cranes Over 50 Tons or Backhoes 115,000 Lbs. or More); Tug, Launch or Loader, Dozer or Like Equipment When Operated on a Barge, Breakwater Wall, Slip, Dock or Scow, Deck Machinery.	26.80	18.52	45.32
540	Work Performed on the Great Lakes Including Deck Equipment Operator, Machineryman or Fireman (Operates 4 Units or More or Maintains Cranes 50 Tons or Under or Backhoes 115,000 Lbs. or Under); Deck Hand, Deck Engineer or Assistant Tug Operator; Off Road Trucks-Great Lakes ONLY.	26.80	18.52	45.32

LOCAL STREET OR MISCELLANEOUS PAVING CONSTRUCTION

Includes roads, streets, alleys, trails, bridges, paths, racetracks, parking lots and driveways (except residential or agricultural), public sidewalks or other similar projects (excluding projects awarded by the Wisconsin Department of Transportation).

SKILLED TRADES

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
103	Bricklayer, Blocklayer or Stonemason	35.53	15.92	51.45
105	Carpenter	29.06	15.16	44.22
107	Cement Finisher	27.57	16.33	43.90
109	Electrician Future Increase(s): Add $.50/hr. effective 06/04/2012. Premium Increase(s): DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.	28.74	17.86	46.60
111	Fence Erector	27.00	0.00	27.00
116	Ironworker	31.31	21.54	52.85
118	Line Constructor (Electrical)	35.97	18.08	54.05
124	Painter	28.47	16.74	45.21
125	Pavement Marking Operator	26.00	0.00	26.00
126	Piledriver	28.11	23.94	52.05
133	Roofer or Waterproofer	28.85	14.60	43.45
137	Teledata Technician or Installer	24.65	15.17	39.82
143	Tuckpointer, Caulker or Cleaner	34.30	15.47	49.77
144	Underwater Diver (Except on Great Lakes)	36.20	18.81	55.01
150	Heavy Equipment Operator - ELECTRICAL LINE CONSTRUCTION ONLY	35.42	12.90	48.32
151	Light Equipment Operator -ELECTRICAL LINE CONSTRUCTION ONLY	28.78	14.42	43.20
152	Heavy Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	25.18	13.07	38.25
153	Light Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	23.38	12.48	35.86
154	Groundman - ELECTRICAL LINE CONSTRUCTION ONLY	21.30	10.97	32.27

TRUCK DRIVERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
201	Single Axle or Two Axle	15.00	0.00	15.00
203	Three or More Axle	20.00	6.00	26.00
204	Articulated, Euclid, Dumptor, Off Road Material Hauler Future Increase(s): Add $1/hr on 6/3/2012; Add $1/hr on 6/2/2013.	31.89	17.98	49.87
205	Pavement Marking Vehicle	19.25	10.84	30.09
206	Shadow or Pilot Vehicle	15.00	0.00	15.00
207	Truck Mechanic	20.00	6.00	26.00

LABORERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
301	General Laborer	21.73	17.04	38.77
303	Landscaper	22.96	15.37	38.33
304	Flagperson or Traffic Control Person Future Increase(s): Add $1.60/hr on 6/1/2012; Add $1.70/hr on 6/1/2013; Add $1.60/hr on 6/1/2014. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr when the Wisconsin Department of Transportation or responsible governing agency requires that work be performed at night under artificial illumination with traffic control and the work is completed after sunset and before sunrise.	23.55	13.45	37.00
311	Fiber Optic Laborer (Outside, Other Than Concrete Encased)	17.09	14.40	31.49
314	Railroad Track Laborer	17.00	1.06	18.06

HEAVY EQUIPMENT OPERATORS
CONCRETE PAVEMENT OR BRIDGE WORK

Fringe Benefits Must Be Paid On All Hours Worked

CODE	TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
541	Crane, Tower Crane, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of Over 100 Tons, Self-Erecting Tower Crane With a Lifting Capacity Of Over 4,000 Lbs., Crane With Boom Dollies; Crane, Tower Crane, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 176 Ft or Over; Master Mechanic. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	34.22	18.90	53.12
542	Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of 130,000 Lbs. or Over; Caisson Rig; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of 100 Tons or Under, Self-Erecting Tower Crane With a Lifting Capacity of 4,000 Lbs. & Under; Crane, Tower Crane Portable Tower, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 175 Ft or Under; Dredge (NOT Performing Work on the Great Lakes); Licensed Boat Pilot (NOT Performing Work on the Great Lakes); Pile Driver. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	33.72	18.90	52.62

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
543	Air Track, Rotary or Percussion Drilling Machine &/or Hammers, Blaster; Automatic Subgrader (Concrete); Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of Under 130,000 Lbs., Backhoe (Mini, 15,000 Lbs. & Under); Boring Machine (Directional, Horizontal or Vertical); Bridge (Bidwell) Paver; Bulldozer or Endloader; Concrete Batch Plant, Batch Hopper; Concrete Breaker (Large, Auto, Vibratory/Sonic, Manual or Remote); Concrete Bump Cutter, Grinder, Planing or Grooving Machine; Concrete Conveyor System; Concrete Laser/Screed; Concrete Paver (Slipform); Concrete Pump, Concrete Conveyor (Rotec or Bidwell Type); Concrete Slipform Placer Curb & Gutter Machine; Concrete Spreader & Distributor; Crane (Carry Deck, Mini) or Truck Mounted Hydraulic Crane (10 Tons or Under); Crane With a Lifting Capacity of 25 Tons or Under; Forestry Equipment, Timbco, Tree Shear, Tub Grinder, Processor; Gradall (Cruz-Aire Type); Grader or Motor Patrol; Grout Pump; Hydro-Blaster (10,000 PSI or Over); Loading Machine (Conveyor); Manhoist; Material or Stack Hoist; Mechanic or Welder; Milling Machine; Post Hole Digger or Driver; Scraper (Self Propelled or Tractor Drawn) 5 cu yds or More Capacity; Shoulder Widener; Sideboom; Skid Rig; Stabilizing or Concrete Mixer (Self-Propelled or 14S or Over); Straddle Carrier or Travel Lift; Tractor (Scraper, Dozer, Pusher, Loader); Tractor or Truck Mounted Hydraulic Backhoe; Trencher (Wheel Type or Chain Type); Tube Finisher; Tugger (NOT Performing Work on the Great Lakes); Winches & A-Frames.	31.89	18.22	50.11
544	Backfiller; Belting, Burlap, Texturing Machine; Broom or Sweeper; Compactor (Self-Propelled or Tractor Mounted, Towed & Light Equipment); Concrete Finishing Machine (Road Type); Environmental Burner; Farm or Industrial Type Tractor; Fireman (Pile Driver & Derrick NOT Performing Work on the Great Lakes); Forklift; Greaser; Jeep Digger; Joint Sawer (Multiple Blade); Launch (NOT Performing Work on the Great Lakes); Lift Slab Machine; Mechanical Float; Mulcher; Power Subgrader; Robotic Tool Carrier (WIth or Without Attachments); Self Propelled Chip Spreader; Shouldering Machine; Skid Steer Loader (With or Without Attachments); Telehandler; Tining or Curing Machine. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	33.22	18.90	52.12

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
545	Air Compressor (&/or 400 CFM or Over); Air, Electric or Hydraulic Jacking System; Automatic Belt Conveyor & Surge Bin; Boiler (Temporary Heat); Concrete Proportioning Plant; Crusher, Screening or Wash Plant; Generator (&/or 150 KW or Over); Heaters (Mechanical); High Pressure Utility Locating Machine (Daylighting Machine); Mudjack; Oiler; Prestress Machine; Pug Mill; Pump (3 Inch or Over) or Well Points; Rock, Stone Breaker; Screed (Milling Machine); Stump Chipper; Tank Car Heaters; Vibratory Hammer or Extractor, Power Pack.	30.42	17.58	48.00
546	Fiber Optic Cable Equipment.	24.39	15.45	39.84
547	Work Performed on the Great Lakes Including Diver; Wet Tender or Hydraulic Dredge Engineer.	36.20	18.81	55.01
548	Work Performed on the Great Lakes Including 70 Ton & Over Tug Operator; Assistant Hydraulic Dredge Engineer; Crane or Backhoe Operator; Hydraulic Dredge Leverman or Diver's Tender; Mechanic or Welder.	36.20	18.81	55.01
549	Work Performed on the Great Lakes Including Deck Equipment Operator or Machineryman (Maintains Cranes Over 50 Tons or Backhoes 115,000 Lbs. or more); Tug, Launch or Loader, Dozer or Like Equipment When Operated on a Barge, Breakwater Wall, Slip, Dock or Scow, Deck Machinery.	26.80	18.52	45.32
550	Work Performed on the Great Lakes Including Deck Equipment Operator; Machineryman or Fireman (Operates 4 Units or More or Maintains Cranes 50 Tons or Under or Backhoes 115,000 Lbs. or Under); Deck Hand, Deck Engineer or Assistant Tug Operator; Off Road Trucks - Great Lakes ONLY.	26.80	18.52	45.32

HEAVY EQUIPMENT OPERATORS
ASPHALT PAVEMENT OR OTHER WORK

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
551	Crane, Tower Crane, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of Over 100 Tons, Self Erecting Tower Crane With a Lifting Capacity of Over 4,000 Lbs., Crane With Boom Dollies; Crane, Tower Crane, Pedestal Tower or Derrick, With Boom, Leads and/or Jib Lengths Measuring 176 Ft or Over; Master Mechanic.	38.06	18.10	56.16

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
552	Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of 130,000 Lbs. or Over; Caisson Rig; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of 100 Tons or Under, Self-Erecting Tower Crane With a Lifting Capacity Of 4,000 Lbs. & Under; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 175 Ft or Under; Dredge (NOT Performing Work on the Great Lakes); Licensed Boat Pilot (NOT Performing Work on the Great Lakes); Pile Driver. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14. Premium Increase(s): DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add $1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).	33.72	18.90	52.62
553	Air, Track, Rotary or Percussion Drilling Machine &/or Hammers, Blaster; Asphalt Heater, Planer & Scarifier; Asphalt Milling Machine; Asphalt Screed; Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of Under 130,000 Lbs., Backhoe (Mini, 15,000 Lbs. & Under); Bituminous (Asphalt) Plant & Paver, Screed; Boring Machine (Directional, Horizontal or Vertical); Bulldozer or Endloader; Concrete Breaker (Large, Auto, Vibratory/Sonic, Manual or Remote); Concrete Conveyor System; Concrete Laser/Screed; Concrete Slipform Placer Curb & Gutter Machine; Crane (Carry Deck, Mini) or Truck Mounted Hydraulic Crane (10 Tons or Under); Crane With a Lifting Capacity of 25 Tons or Under; Forestry Equipment, Timbco, Tree Shear, Tub Grinder, Processor; Gradall (Cruz-Aire Type); Grader or Motor Patrol; Hydro-Blaster (10,000 PSI or Over); Loading Machine (Conveyor); Manhoist; Material or Stack Hoist; Mechanic or Welder; Milling Machine; Post Hole Digger or Driver; Railroad Track Rail Leveling Machine, Tie Placer, Extractor, Tamper, Stone Leveler or Rehabilitation Equipment; Roller (Over 5 Ton); Scraper (Self Propelled or Tractor Drawn) 5 cu yds or More Capacity; Shoulder Widener; Sideboom; Skid Rig; Stabilizing or Concrete Mixer (Self-Propelled or 14S or Over); Tractor (Scraper, Dozer, Pusher, Loader); Tractor or Truck Mounted Hydraulic Backhoe; Trencher (Wheel Type or Chain Type); Tube Finisher; Tugger (NOT Performing Work on the Great Lakes); Winches & A-Frames.	31.52	17.50	49.02

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
554	Backfiller; Broom or Sweeper; Compactor (Self-Propelled or Tractor Mounted, Towed & Light Equipment); Concrete Finishing Machine (Road Type); Environmental Burner; Farm or Industrial Type Tractor; Fireman (Asphalt Plant, Pile Driver & Derrick NOT Performing Work on the Great Lakes); Forklift; Greaser; Hoist (Tugger, Automatic); Jeep Digger; Joint Sawer (Multiple Blade); Launch (NOT Performing Work on the Great Lakes); Lift Slab Machine; Mechanical Float; Mulcher; Power Subgrader; Robotic Tool Carrier (With or Without Attachments); Roller (Rubber Tire, 5 Ton or Under); Self-Propelled Chip Spreader; Shouldering Machine; Skid Steer Loader (With or Without Attachments); Telehandler. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14.	32.67	18.55	51.22
555	Air Compressor (&/or 400 CFM or Over); Air, Electric or Hydraulic Jacking System; Augers (Vertical & Horizontal); Automatic Belt Conveyor & Surge Bin; Boiler (Temporary Heat); Crusher, Screening or Wash Plant; Generator (&/or 150 KW or Over); Heaters (Mechanical); High Pressure Utility Locating Machine (Daylighting Machine); Mudjack; Oiler; Prestress Machine; Pug Mill; Pump (3 Inch or Over) or Well Points; Rock, Stone Breaker; Screed (Milling Machine); Stump Chipper; Tank Car Heaters; Vibratory Hammer or Extractor, Power Pack. Future Increase(s): Add $2/hr on 6/1/12; Add $2/hr on 6/1/13; Add $1.75/hr on 6/1/14.	32.67	18.55	51.22
556	Fiber Optic Cable Equipment.	24.39	15.45	39.84

RESIDENTIAL OR AGRICULTURAL CONSTRUCTION

Includes single family houses or apartment buildings of no more than four (4) stories in height and all buildings, structures or facilities that are primarily used for agricultural or farming purposes, excluding commercial buildings. For classification purposes, the exterior height of a residential building, in terms of stories, is the primary consideration. All incidental items such as site work, driveways, parking lots, private sidewalks, private septic systems or sewer and water laterals connected to a public system and swimming pools are included within this definition. Residential buildings of five (5) stories and above are NOT included within this definition.

SKILLED TRADES

Fringe Benefits Must Be Paid On All Hours Worked

CODE	TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
101	Acoustic Ceiling Tile Installer	27.00	1.16	28.16
102	Boilermaker	31.09	21.87	52.96
103	Bricklayer, Blocklayer or Stonemason	26.22	13.80	40.02
104	Cabinet Installer	26.00	2.33	28.33
105	Carpenter	31.68	7.03	38.71
106	Carpet Layer or Soft Floor Coverer	21.40	6.01	27.41
107	Cement Finisher	28.00	10.10	38.10
108	Drywall Taper or Finisher Future Increase(s): Add $2.20/hr on 6/1/2012	28.97	17.74	46.71
109	Electrician	31.10	6.01	37.11
110	Elevator Constructor	43.79	25.48	69.27
111	Fence Erector	17.64	4.66	22.30
112	Fire Sprinkler Fitter	36.39	16.97	53.36
113	Glazier	36.23	8.04	44.27
114	Heat or Frost Insulator	29.04	19.73	48.77
115	Insulator (Batt or Blown)	11.00	2.51	13.51
116	Ironworker	23.05	4.06	27.11
117	Lather	28.15	15.14	43.29
119	Marble Finisher	31.16	16.27	47.43
120	Marble Mason	35.53	15.92	51.45
121	Metal Building Erector	15.19	2.00	17.19
123	Overhead Door Installer	23.00	8.00	31.00
124	Painter	23.00	2.81	25.81

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
125	Pavement Marking Operator	26.00	0.00	26.00
129	Plasterer	30.36	7.15	37.51
130	Plumber	37.42	17.92	55.34
132	Refrigeration Mechanic	25.00	0.51	25.51
133	Roofer or Waterproofer Future Increase(s): Add $.50/hr. effective 06/01/2012	29.40	15.05	44.45
134	Sheet Metal Worker	28.15	15.14	43.29
135	Steamfitter	32.59	11.05	43.64
137	Teledata Technician or Installer	19.23	5.32	24.55
138	Temperature Control Installer	22.00	2.64	24.64
139	Terrazzo Finisher	18.00	5.35	23.35
140	Terrazzo Mechanic	31.16	16.27	47.43
141	Tile Finisher	23.96	15.50	39.46
142	Tile Setter	27.00	1.91	28.91
143	Tuckpointer, Caulker or Cleaner	32.50	1.62	34.12
146	Well Driller or Pump Installer	27.60	0.00	27.60
147	Siding Installer	16.00	0.00	16.00

TRUCK DRIVERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
201	Single Axle or Two Axle	16.25	2.25	18.50
203	Three or More Axle	17.00	7.63	24.63
205	Pavement Marking Vehicle	19.25	10.84	30.09
207	Truck Mechanic	19.00	1.75	20.75

LABORERS

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
301	General Laborer	17.50	6.16	23.66
302	Asbestos Abatement Worker	17.00	2.21	19.21
303	Landscaper	11.00	2.07	13.07
311	Fiber Optic Laborer (Outside, Other Than Concrete Encased)	17.09	14.40	31.49

HEAVY EQUIPMENT OPERATORS RESIDENTIAL OR AGRICULTURAL CONSTRUCTION

CODE	Fringe Benefits Must Be Paid On All Hours Worked TRADE OR OCCUPATION	HOURLY BASIC RATE OF PAY $	HOURLY FRINGE BENEFITS $	TOTAL $
557	Asphalt Heater, Planer & Scarifier; Asphalt Milling Machine; Asphalt Screed; Backhoe (Track Type); Backhoe (Mini, 15,000 Lbs. & Under); Bituminous (Asphalt) Plant & Paver, Screed; Boring Machine (Directional, Horizontal or Vertical); Bulldozer or Endloader; Concrete Breaker (Large, Auto, VIbratory/Sonic, Manual or Remote); Concrete Bump Cutter, Grinder, Planing or Grooving Machine; Concrete Conveyor System; Concrete Laser/Screed; Concrete Paver (Slipform); Concrete Pump, Concrete Conveyor (Rotec or Bidwell Type); Concrete Slipform Placer Curb & Gutter Machine; Concrete Spreader & DIstributor; Crane (Carry Deck, Mini) or Truck Mounted Hydraulic Crane (10 Tons or Under); Crane With a Lifting Capacity of 25 Tons or Under; Crane, Shovel, Dragline, Clamshells; Forestry Equipment, TImbco, Tree Shear, Tub Grinder, Processor; Grader or Motor Patrol; Grout Pump; Hydro-Blaster (10,000 PSI or Over); Loading Machine (Conveyor); Manhoist; Material or Stack Hoist; Mechanic or Welder; Milling Machine; Roller (Over 5 Ton); Scraper (Self Propelled or Tractor Drawn) 5 cu yds or More Capacity; Shoulder Widener; Skid Rig; Stabilizing or Concrete Mixer (Self-Propelled or 14S or Over); Tractor (Scraper, Dozer, Pusher, Loader); Tractor or Truck Mounted Hydraulic Backhoe; Tractor or Truck Mounted Hydraulic Crane (10 Tons or Under); Trencher (Wheel Type or Chain Type); WInches & A-Frames.	32.56	10.76	43.32
558	Air Compressor (&/or 400 CFM or Over); Air, Electric or Hydraulic Jacking System; Backfiller; Belting, Burlap, Texturing Machine; Boiler (Temporary Heat); Broom or Sweeper; Compactor (Self-Propelled or Tractor Mounted, Towed & LIght Equipment); Concrete Finishing Machine (Road Type); Farm or Industrial Type Tractor; Forklift; Generator (&/or 150 KW or Over); Heaters (Mechanical); High Pressure Utility Locating Machine (Daylighting Machine); Jeep Digger; Lift Slab Machine; Mulcher; Oiler; Post Hole Digger or Driver; Power Subgrader; Pump (3 Inch or Over) or Well Points; Robotic Tool Carrier (With or Without Attachments); Rock, Stone Breaker; Roller (Rubber Tire, 5 Tons or Under); Screed (Milling Machine); Self Propelled Chip Spreader; Shouldering Machine; Skid Steer Loader (With or Without Attachments); Stump Chipper; Telehandler; Vibratory Hammer or Extractor, Power Pack.	17.40	0.44	17.84

********** END OF RATES **********

SECTION 00850: DRAWING SCHEDULE

The following listed drawings accompany and form a part of the project contract documents along with this project manual and generally illustrate the nature of the work.

INDEX OF DRAWINGS:

C-1 Title Sheet, Site Location Plan, Contents
A100 Existing Roofing Plan
A101 Existing Quadrant Roofing Plans
A200 New Roofing Plan
A201 New Quadrant Roofing Plans
A300 New Roof insulation Plan
A301 Details

SECTION 01010: SUMMARY OF WORK:

1. SCOPE:

   A. Index:
      1. Scope
      2. Project Description
      3. Work by Others
      4. Scheduling of Work

2. PROJECT DESCRIPTION:

   A. In general, the project includes removal of existing EPDM and built-up roofing, and reinstallation of new hot applied built up roofing, insulation and accessories on the 1st floor quadrants and 3rd floor roofs.

      Alternate Bid 1 includes removal of the built up roofing and reinstallation of new hot applied built up roofing, insulation and accessories on the 2nd floor roof.

      AT&T will remove grating and 2" rigid piping on the 1st floor southwest quadrant.

   B. The City will occupy the site during construction. The contractor is required to coordinate all construction with the City or agent to minimize impact to City operations and to ensure the safety of City employees and property. Coordination shall include the placement of field offices, public protection canopies, construction site fencing, scaffolding, interruption of utility service, demolition of existing building exterior concrete and antennas, delivery and storage of materials, installation of new antennas and accessories, and repair of building facade.

   C. It is understood that the submittal of a proposal shall include furnishing all labor, materials, equipment, and incidentals necessary for completion of the work required, including that which may not be directly shown on the drawings or in the specifications, but are necessary for proper operation and approval.

   D. Examine Documents and Visit Site:

      1. Before submitting a bid proposal, bidders should carefully examine the drawings and specifications; visit the site of work; fully inform themselves as to all existing conditions and limitations including those of labor; and shall include in the bid proposal a sum sufficient to cover the cost of all items contemplated by the construction documents.

      2. Each sub-bidder further represents that he has inspected the site of the proposed work to ascertain any obstacles that might be encountered and other matters and conditions relevant to this work.

      3. The nature of the work required demands thorough review of all drawings and the project manual, and diligent and careful site inspection by all prospective sub-bidders as a means of determining the extent of work and conditions under which the work is to be performed.

      4. Additional charges will not be as considered for work which, prior to bidding, could reasonably be inferred as appropriate by examination of the drawings and specifications, visiting the site, and closely reviewing the work as indicated above. No representations as to subsurface conditions are made.

E. The following outline is intended to serve as a general guide only and not as a complete listing of work, operations, or materials. Consult the Table of Contents for complete listing of items included.

1. Removal and salvage of gravel on built up roofs.

2. Removal and disposal of existing built up roofing material, insulation and accessories.

3. Removal and disposal of EPDM roofing material, insulation and accessories.

4. Cleaning of roof surface

5. Installation of elastomeric flexible flashing, vapor barrier, tapered insulation, class A sheet backing at parapets, hot applied built up roofing materials, counterflashing, coping cap and accessories.

6. AT&T will reinstall grating and rigid conduit after the roofing on the 1st floor southwest quadrant has been completed.

3. SEQUENCE OF WORK

A. AT&T to remove grating and two inch rigid piping from 1st floor southwest quadrant roof.

B. Install protection for building staff and their vehicles, and for landscaping. .

C. Remove gravel and salvage. Remove existing roofing and accessories and dispose of.

D. Clean roof surfaces, apply new vapor barrier, insulation, roofing accessories, and built-up roofing. Install new coping cap.

4. WORK BY OTHERS:

A. Removal of AT&T equipment by AT&T or their contractor.

B. Any building electrical, data or telephone work by City of Milwaukee.

5. SCHEDULING OF WORK:

A. A preconstruction conference will be held prior to the start of work.

B. All work unless otherwise specifically approved or noted, is to be done during normal working hours.

C. Contractor must notify the City 48 hours in advance before starting work.

D. The contractor shall sign in and identify all personnel working at the site on a daily basis with the supervisor in charge at the site. All personnel leaving the site will sign out prior to departure.

E. Shut downs of existing equipment and connections to existing equipment must be arranged in advance with the Project Inspector from Facilities Development and Management. Power outages must be scheduled for Saturdays.

E. Dispose of all removed materials in legal manner.

F. The contractor shall provide a construction schedule which includes all phases of construction. The contractor shall provide that complete schedule at the Pre-Construction Meeting arranged by the City.

H. Project Total working days includes submittals and submittal approval, acquisition and preparation of materials, and work off-site.

END OF SECTION

SECTION 01210: PROJECT MEETINGS

1. SCOPE:

   A. Index:

      1. Scope
      2. Pre-Construction Meeting
      3. Progress Meetings

2. PRE-CONSTRUCTION MEETING:

   A. Soon after the award of the contract and prior to the start of construction, the contractor shall attend a pre-construction conference with representatives of the City.

   B. The contractor shall have at the meeting responsible representatives from subcontractors who are to perform major work on the project.

   C. The purpose of the meeting is to discuss in detail the plans and specifications. The discussion shall include:

      1. Schedule
      2. Equipment/Delivery Dates
      3. Material Storage
      4. Inspection Requirements
      5. Protection Procedures for the structure, adjacent facilities, environment, and personnel.
      6. Hours of Work

   D. The contractor shall submit the construction schedule to the architect/engineer at this meeting and a listing of subcontractors and their work. The contractor shall describe, in detail, when each portion of the work is expected to be accomplished. The subcontractors shall participate in the discussion. The architect/engineer will serve to interpret the contract documents should such questions arise.

   E. Any other questions that the contractor or his subcontractors have about the work or its scheduling shall be raised at these meetings.

   F. Requirements for contract administration and construction operations will be defined for participants.

   G. The architect/engineer will determine time, date, and place of the meeting.

3. PROGRESS MEETINGS:

   A. Bi-weekly meetings will be held for the purpose of coordinating and expediting the work.

   B. Attendance at project meetings by the contractor is mandatory. These meetings shall also be attended by representatives of each subcontractor who is either working at the site or is affected by work being done at the site. The contractor shall submit an updated construction schedule at these meetings and a short narrative should be written, describing the cause of any delays and intended action to remedy these delays.

   C. Contractors shall give a verbal report of progress on the project, discuss the work schedule for the coming period, and present all conflicts, discrepancies or other difficulties for resolution.

SECTION 01300: SUBMITTALS/PERMITS

1. SCOPE:

A. Index:

1. Scope
2. Submittals
3. Permits
4. Inspection

2. SUBMITTALS:

A. Comply with the requirements of the General Conditions and as follows:

1. Forward Submittals not more than 20 calendar days after the Notice to Proceed date. No work, as indicated on any shop drawing, samples, hardware list, etc., shall be started until those submittals have been reviewed and work authorized.

2. All submittals must be thoroughly reviewed by the prime contractor for conformance to contract documents, prior to submission to the City, or its agents, for review. Shop drawings and catalog information shall be stamped "Reviewed By" and signed by the contractor's reviewer. The prime contractor shall review all subcontractor submittals prior to submittal to the City for compliance with contract documents and to coordinate all work.

3. Include with each submittal a transmittal letter signed and dated by the prime contractor containing the following:

a. Name of Contractor
b. Name of Project
c. List of Submittals
d. Name of Manufacturer or Supplier
e. Additional information as required for the items being provided.

B. Shop Drawings, Catalog Information, Calculations, and Samples:

1. Shop Drawings: Submit four blue/black line print review. The City will notify the contractor in writing and return one copy marked "REVIEWED - NO EXCEPTIONS TAKEN" with minor or no notations. The City will also notify the contractor in writing and return one copy, along with comments, when the drawings are marked either "REJECTED" or "REVISE AND RESUBMIT". For those shop drawings, the contractor will be responsible for resubmitting a new print. Shop drawings required for insulation plan, stepped wall details, retro fit drains, wall flashing, parapet and penetrations.

2. Catalog Information and Calculations: Submit four copies for City's record and additional numbers of copies required for the contractor's purpose. The City will notify the contractor in writing and return the contractor's copies, with or without notation, marked either "REVIEWED - NO EXCEPTIONS TAKEN", "REVISE AND RESUBMIT", OR "REJECTED". Catalog information or calculations marked "REVISE AND RESUBMIT" or "REJECTED" must be resubmitted in the same quantities as originally required.

REV 7/09

3. Samples: Submit two samples of requested materials for the City's records and additional samples, if desired, to be returned to the contractor. The City will notify the contractor in writing, whether the samples are approved or rejected. If they are rejected, new samples must be resubmitted as originally required.

4. Corrections or comments made on the submittals during the review do not relieve the contractor from compliance with requirements of the contract documents. The check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. Contractors are responsible for conforming and correlating all quantities and dimensions; selecting fabrication processes and techniques of construction; coordinating their work with that of all other trades; and performing their work in a safe manner.

C. "Or Equal": Whenever the words "or equal" or similar term is used, it shall mean as determined by the Commissioner of Public Works or agent. All drawings, data and bulletins necessary to make an "or equal" determination shall be submitted to the Facilities Manager of FACILITIES DEVELOPMENT AND MANAGEMENT SECTION. Such review shall apply to design only and shall in no way relieve the contractor from the responsibilities as outlined in Item 2B above. Evaluation of "or equal" products will be made at the time of shop drawing submission. Any change required in design and coordination between all contractors, subcontractors, or trades due to the use of "or equal" materials shall become the contractor's responsibility. Any costs for detailed engineering reviews and/or any costs to incorporate "or equal" products will be borne by the contractor.

3. PERMITS:

A. The City of Milwaukee will provide the general construction and occupancy permits.

B. Contractors shall obtain, from the City of Milwaukee Department of City Development and/or other government or private agencies, all special permits as may be necessary in their work.

C. Contractors shall obtain all permits to occupy or work in the public way as may be necessary for their work.

D. Contractors shall notify the City and/or appropriate utilities when making utility connections as part of the project.

4. INSPECTION:

REV 1/10

A. FACILITIES DEVELOPMENT AND MANAGEMENT SECTION will provide daily inspection to verify compliance with contract documents, identify contractors and crews on the job, verify compliance with contract conditions (EBE, residency, wage requirements), and record job progress and conditions.

REV 1/04

B. Contractors shall arrange with the Department of Neighborhood Services/Construction Trades Division and permit issuing agencies for all code compliance inspections as required by all permits including, but not limited to, the general building and all special permits issued by that agency.

D. Contractors shall arrange with the appropriate City agency for compliance inspections, as required, for all permits including, but not limited to, curb and pavement cuts and patches, and public way occupancy and utility connections.

REV 7/99

SECTION 01500: JOB SITE UTILITIES, FACILITIES, AND SECURITY

1. SCOPE:

A. Index:

1. Scope
2. Building Security
3 Temporary or Trial Usage
4. Occupancy During Construction
5. Temporary Hoists, Lifts
6. Scaffolding
7. Electrical Power
8. Water
9. Temporary Toilet Facilities
10. Site Security
11. Parking

1. Scope:

The following building security policy and procedure statement has been provided in this project manual for bid consideration and shall be distributed at the Pre-Construction Meeting. All City agents/officials responsible for engaging contractors, all contractors, and all subcontractors shall be held responsible for following the procedures.

2. BUILDING SECURITY:

A. General:

The Downtown Complex is open to the public from 8:00 AM until 4:45 PM, Monday through Friday, excluding holidays. Since most contracted work takes place outside normal business hours, it is essential that contractors and their City agents understand and abide by security policy.

Outlying buildings are not generally open to the public. Contracted work in these buildings can take place at any time. It is essential that contractors and their City agents understand and abide by security policy.

B. Police Access (General):

1. Access to Milwaukee Police Department facilities requires the contractor to meet the access procedures described below.

2. The Police Department requires that all contractors, vendors, visitors or other who intend to do business at any Police Department site must have a background check performed by the Milwaukee Police Department **PRIOR** to any access.

3. All contractors' staff requiring access to the site, including any subcontractors, suppliers or vendors, will be required to submit their full name (including full middle name) and birth date to allow the Department to perform the necessary background check. The contractor shall provide a staff list two weeks before work begins. At this time, the contractor shall provide a brief outline of the work, project schedule, and company contact information (company name, contact name and title, phone number and address).

4. To add staff during the course of the project, provide the same information as above and allow 48 hours for a response.

5. The Contractor will be notified if the worker does not pass the background check.

6. Sign in and sign out will be required at all Milwaukee Police Department facilities.

C. City Agents/Officials:

1. Any City agents/officials who commission outside contractors to work in any of the facilities managed by FACILITIES DEVELOPMENT AND MANAGEMENT SECTION shall provide the following information no less than twenty-four (24) hours in advance of the work:

   a. The names of any contract or subcontract employees who will be present in the facilities (for the purpose of designing badges appropriate to their work area):
   Green – Zeidler Municipal Building, 841 North Broadway
   Red – City Hall, 200 East Wells Street
   Yellow – 809 North Broadway
   Gold – Any outlying buildings

   These names must be listed on a sign-in sheet available in the Zeidler Municipal Building, Room 602 (FACILITIES DEVELOPMENT AND MANAGEMENT SECTION support staff – Extension 8222). City agents/officials shall be responsible to ensure the sheet and badges are transported to the appropriate location where the work is to be completed (in the Downtown Complex it would go to the City Hall Information Center, for outlying buildings to the person responsible for controlling access in the facility) the day before work is to begin.

   b. A list of keys and/or access cards required for access only to the areas necessary for work involved in the project. The keys and card will be received from the Security Manager or his designee and signed out to the City agents/officials responsible for the contracted work. The City employee will take the keys and/or access cards to the City Hall Information Center or the person responsible for controlling access in the outlying building where they shall be logged under the name of the contractor's company. When a project is complete, the City agents/officials must retrieve the keys/cards and return them to FACILITIES DEVELOPMENT AND MANAGEMENT SECTION support staff in Room 602 of the Zeidler Municipal Building.

c. The City agents/officials are responsible for communicating the security policy and procedures to contractors. The City agents/officials shall act as liaison for all communication between FACILITIES DEVELOPMENT AND MANAGEMENT SECTION and the contractor.

D. Contractors:

1. Contractors shall abide by City security policy and procedures at all times during the scope of their participation in a project. Failure to comply will result in the contracted employee being escorted from the premises and the resulting lost time and expense shall be deducted from the contractor's invoice or penalties of $50.00 per occurrence as determined by the contracting City agent/official.

a. All access should be provided in advance through the City agent/official. Contractors shall enter and exit only through those doors designated by City agents/officials (the Market Street entrance to City Hall and the doors established by the person responsible for access at outlying buildings). All other exterior doors are locked and alarmed and are not to be used as delivery points unless the City agent/official has been provided 24 hour notification to provide additional security coverage at that point while the delivery is in progress.

b. All of the contractor's employees and all of the employees of any of his subcontractors shall wear at all times while on the site, in a clearly visible location, an identification card. The identification card is to have a minimum 1" x 1" color photo of the head and shoulders. The photo is to have been taken no more than one year previously. The card is to be laminated with clear plastic and is to contain the company name, employee's name, and the employee's signature, and is to be furnished by the contractor or respective subcontractor.

c. Effective October 1, 2004 – City of Milwaukee Policy Change

The following policy has been established to maintain control of City Property and to ensure the physical protection of the City Hall Complex.

Anyone signing out access cards and/or keys from the Information Center will be following the steps below:

1) Sign in on the sheet assigned to the project you are working on and pull that sheet and provide it to the Operator noting that you will need to sign out City property to access the building.

2) Provide the Operator your driver's license as collateral for the return of City property.

3) Sign out the property in the sign out book as per current policy.

4) The Operator will file your driver's license until such time as you sign in and return the City property at which time your license will be returned.

5) Sign out at the end of your workday on the sign out sheet.

6) Under NO circumstances will keys or cards be disbursed without the user signing for the property and providing the City Hall Operator their driver's license as collateral.

7) In the event that keys or cards are not returned daily the contractor in question will have a deduct (security violation) **$50.00 penalty** for each occurrence, as per the contract. Individuals who loose or fail to return keys will be responsible for the cost of re-keying to the City.

8) Contractors shall not ask custodians or mechanics to unlock doors. All access should be provided in advance through the City agent/official. In the rare case where access is not provided, the City Hall Operator may be contacted to assist in providing access. The contractor shall cooperate with security personnel at all times. The contractor should be prepared to allow searches of equipment when leaving, and should remain only in the areas designated on the sign-in sheets.

e. If the contractor requires use of the loading dock in Upper Parking, 24 hour advance notice shall be given to the City agent/official to make arrangements to provide additional security coverage while the delivery is in progress. The contractor or subcontractor shall meet the delivery driver and take delivery at that point. At no time shall a driver be allowed in the facilities without following the access procedure stated above.

f. If after normal business hours work is required in the outlying buildings, all subcontractors and trades will arrange appropriate security measures and lock-up procedures with the contractor in writing. Any work completed at night shall be left "open" for City inspection of the work. The contractor shall notify the City agent/official 24 hours in advance of after-hours work in writing, indicating the type of work to be done and the security measures to be taken by the contractor.

g. The contractor shall provide plywood door and window closures during construction to secure the structure from weather and damage from vandalism. The contractor is responsible to maintain the security of the space where they are working during construction.

h. If proper notification is not provided to the contractor, the subcontractor or trades shall be liable for any subsequent damage/vandalism/inspection cost, etc., due to lack of security/inspection coordination.

i. Use of City materials is strictly prohibited unless pre-arranged through the City employee contact.

j. At no time shall any interior doors that control access or exterior doors be propped open.

3. TEMPORARY OR TRIAL USAGE:

The owner shall have the right to make temporary or trial usage of any mechanical device, machinery, apparatus, equipment, work, material or construction supplied under contract before final completion or acceptance of the work, and the same shall not be construed as evidence of acceptance of the work by the owner.

4. OCCUPANCY DURING CONSTRUCTION:

The owner will occupy the premises while work is in progress. Contractor is to coordinate his work as to not interfere with the owner's operation or compromise building security.

5. TEMPORARY HOISTS, LIFTS

Contractors and subcontractors requiring hoists or lifts shall provide their own and remove upon completion of work.

6. SCAFFOLDING, SWING STAGES, AND LIFTS:

General Contractor shall provide protective sidewalk scaffolding and any additional measures as required to protect the public and allow safe use of this entrance into the facility during the entire construction period.

All scaffolding, swing stages and lifts as required to perform work defined in this contract document shall be provided and maintained by the General Contractor and shall be removed when no longer needed. The General Contractor is solely responsible for the design, safety and security of any scaffolding erected under this contract for this project. All scaffolding, swing stages and lifts shall be available with operators for access to the project for the Project Engineer, City Liaison and City Inspectors.

Exterior scaffolding access (up & down) shall be provided. Access through to the facility will be strictly limited. Adequate security must be provided by the General Contractor to limit the opportunity of unauthorized access of scaffolding.

Submittals for the scaffolding and egress protection shall be provided and reviewed before proceeding with erection. Scaffolding and egress protection submittals shall be stamped by a professional engineer. The scaffolding engineer shall design any foundations or anchoring points as required. The scaffolding system shall be properly grounded.

All anchors and other attachments into building shall be limited. All anchors and attachment shall be clearly indicated on submittals. All costs for scaffolding including installation of anchoring, foundation, erection and patching of all anchor and attachment points at the conclusion of the project shall be

included in the base bid. At the completion of the project, the Contractor is to patch all anchor and attachment points. Patching of all anchor or attachment points shall match existing façade materials. On site patching sample shall be provided and approved before proceeding with all patch work. Any damage to sidewalks, pavement or landscaped areas shall be restored to existing pre-construction conditions after the removal of the scaffolding.

Contractor is to verify that the parking and grass areas that surround the building are structurally suitable for placement of scaffolding, lifts or other equipment or materials prior to placement thereof. Verify by investigation and record plans the location of pervious pavement, water wells, or other underground structures not capable of supporting scaffolding, lifts, equipment or materials, and avoid placement of equipment and/or materials over these areas.

7. ELECTRICAL POWER:

Contractor may use existing outlets for power. Contractor to verify power available at site. Contractor is to supply his own lines. OSHA regulations require that employers use either ground fault circuit interrupters or an assured equipment grounding conductor program in addition to any other regulations for equipment grounding conductors. The cost of the current used will be paid for by the City.

8. WATER:

Hose bibs are available as shown on the drawings. Contractor is to verify that location of existing hose bib is suitable for his work, or provide his own source of water. Contractor is to supply his own hoses. Contractor's hose shall be leak free and contractor is to regulate the flow to limit it to project-related use. The cost of water at the building shall be paid for by the City.

9. TEMPORARY TOILET FACILITIES:

The contractor is responsible for providing their own exterior toilet facilities during construction.

10. SITE SECURITY:

Contractor shall secure all doors and gates prior to leaving site.

11. PARKING:

Parking is available off site, on the streets adjacent to the project.

SECTION 01505: CONSTRUCTION WASTE MANAGEMENT

PART 1 - GENERAL

1.1 SCOPE:

A. This section specifies requirements for salvaging, recycling and disposing of construction waste for purposes of protecting the environment and reducing project cost.

Requirements include the following:

1. Developing a Construction Waste Management Plan including waste management goals and provisions for waste reduction and recycling.
2. Implementing, monitoring and documenting the waste management plan.
3. Incorporating special programs.
4. Evaluating construction waste management.

1.2 RELATED DOCUMENTS AND SECTIONS:

A. Drawings and general provisions of the Contract, including General Conditions and other Division 1 Specification Sections, apply to this Section.

B. Related documents include the following

1. Section 01010 “Summary of Work”
2. Section 01300 “Submittal & Permits”
3. Section 01500 “Utilities, Facilities, and Security” for environmental-protection measures during construction.

1.3 PRECONSTRUCTION MEETING:

A. After award of Contract and prior to the commencement of the Work, schedule and conduct a meeting with the Owner and Architect to discuss the proposed Construction Waste Management Plan and to develop a mutual understanding regarding details of environmental protection.

1.4 CONSTRUCTION WASTE MANAGEMENT PLAN:

A. Construction Waste Management Plan

1. The purpose of the Construction Waste Management Plan is to identify construction waste reduction goals, identify targeted materials, and explain specific waste reduction actions to be taken, by whom, and when.
2. The Contractor shall develop a Construction Waste Management Plan for this Project within 15 working days after Contract award or prior to any waste removal. The Owner and the Architect will furnish the Contractor with information that will assist in the development of the Construction Waste Management Plan. Submit the Construction Waste Management Plan (include document/report form) to the Architect for approval prior to implementing the Plan.

B. The Plan, which should be entered into and generated by WasteCapTRACE, shall include the following:

1. **A list of the waste materials expected to be generated from the Project debris.**
2. **A list of each material proposed to be salvaged, reused, recycled and discarded. Identify applicable markets for reuse and recycling. At a minimum, all materials required by state law to be recycled shall be recycled (e.g., cardboard, cans, bottles, office paper, fluorescent tubes, refrigerants, mercury, etc.) and scrap metal shall be recycled.**
3. **Separation and materials handling procedures: Description of how waste materials identified above will be separated, cleaned (if necessary) and protected from contamination.**
4. **Educational and Motivational Procedures: Meetings to be held and other proposed methods for educating construction personnel regarding waste reduction and recycling. Construction waste management requirements should be discussed at least monthly at project site meetings.**
5. **Waste Auditing Procedures: Methods of monitoring and enforcing the Plan.**
6. **Documentation Procedures: Methods of documenting materials leaving the Project site as waste, for the reuse or recycling to allow Summary of Waste Progress Reports to be submitted with Applications for Payment.**
7. **The Lead contractor shall distribute copies of the Construction Waste Management Plan to DPW's Project manager.**

C. Progress Documentation: Document solid waste disposal and diversion. Include the date of removal, type of waste removed, quantity by weight and volume, final destination and use (recycled, reused or landfilled), and net cost or income.

1. Document on the Form acceptable to the Owner and Architect.
2. With each Application for Payment, submit updated documentation identifying solid waste disposal and diversion.
3. With each Application for Payment, submit manifests, weight tickets, receipts and invoices identifying the Project and construction waste material.

D. Record Submittals: Submit the following:

1. Summary of solid waste disposal and diversion. Submit on form acceptable to the Owner and Architect.
2. End-of-Project recycling rates and landfill rates demonstrating the percentage of construction waste that was recycled or reused.

1.5 WASTE MANAGEMENT GOALS:

A. Develop Construction Waste Management Plan that results in end-of-Project rates for the reuse/recycling of 25**%** percent by weight or volume of total waste generated by the Project. Record the total construction waste reduction goal on the Construction Waste Management Plan Form.

B. Reduce: The Project shall generate the least amount of waste and methods shall be used that minimize waste due to error, poor planning, breakage, mishandling, contamination, or similar factors. Promote the resourceful use of materials to the greatest extent possible.

C. Recycle: As many of the waste materials not able to be eliminated in the first place or salvaged for reuse shall be recycled. Waste disposal in landfills shall be minimized to greatest extent possible.

1.6 MATERIALS HANDLING AND SORTING:

A. Handling:

1. Materials that are contaminated prior to placing in collection containers shall be properly cleaned. Deliver materials free of dirt, adhesives, solvents, petroleum contamination, and other substances deleterious to recycling processes.
2. Cover materials with tarps and keep truckloads level so as to prevent spillage.
3. Arrange for collection by or delivery to the appropriate recycling or reuse facility.
4. Hazardous Waste and Hazardous Materials: Handle in accordance with applicable regulations. If encountered, such waste and materials shall be abated under separate contract.

B. The following sorting methods are acceptable:

1. Sorting recyclable materials at the Project site and transporting them to recycling markets directly from the Project site.
2. Employing haulers who make use of a materials-recovery facility or a transfer station where recyclable materials are sorted from the waste and recycled before disposing of the remainder. If using a hauler or recycling facility to sort out recyclables, verify that the hauler sorts out all construction waste loads and is not limited to those that are not acceptable at the landfill. Also, verify that the hauler or recycling facility recycles at least three types of materials.

1.7 WASTE MANAGEMENT PLAN IMPLEMENTATION:

A. The Contractor shall designate a party (or parties) who shall be responsible for instructing construction personnel and overseeing and documenting results of the Construction Waste Management Plan.

B. Distribution: The Contractor shall distribute copies of the Construction Waste Management Plan to the Project Foreman, each Subcontractor, the Owner, and the Architect

C. Instruction: The Contractor shall provide on-site instruction regarding appropriate separation, handling, and recycling, salvage, reuse, and return methods to be used by all construction personnel at the appropriate phases of the Project.

D. Separation Facilities: The Contractor shall lay out and identify a specific area on the Project site to facilitate separation of materials for recycling, salvage, reuse, and return. Recycling and waste bin areas shall be kept neat and clean, and clearly marked to avoid contamination of materials. Materials for recycling include concrete, non-fibrous wallboard, paper, clean corrugated cardboard (no pizza boxes), non-treated wood, metals (steel, aluminum and copper), and glass bottles (no windows). Provide separate containers, preferably near the job trailer, with smaller containers located at convenient places throughout the job site. Empty smaller containers into larger containers every night or when full. Cover outdoor containers to keep out rain, snow, and wind-driven debris. Lock containers whenever site is not in use to prevent illegal dumping.

E. Hazardous Waste: Hazardous waste shall be separated, stored, and disposed of according to applicable regulations.

F. Application for Payments: With each Application for Payment, the Contractor shall submit a Summary of Waste generated by the Project. **This reporting shall take place using WasteCapTRACE, an online documentation system. There is a fee, to be included in the bid, of two cents per square foot of gross construction for use of WasteCapTRACE.** Failure to submit this information shall render the Application for Payment void, thereby delaying the Progress Payment.

G. The Summary of Waste shall contain the following information:

1. The amount (in tons and/or cubic yards) of material landfilled from the Project, the identity of the landfill, and the related disposal cost. Include corresponding manifests, weight tickets, receipts, and invoices.
2. For each material recycled from the Project, the amount (in tons and/or cubic yards), the date removed from the Project site, the receiving party, the transportation cost, the amount of any money paid or received for the recycled or salvaged material, and the net total cost or savings of recycling. Include corresponding manifests, weight tickets, receipts, and invoices.
3. **Final Payment: Prior to application for Final Payment, the Lead Contractor shall submit a Final Summary of Waste: reuse and recycling results for all prime and subcontractors, including the quantity of each material recycled, reused, or salvaged, the receiving party and the applicable diversion rates. The final report will be generated by WasteCapTRACE based on information entered throughout the project by the Lead Contractor.**

H. Implementing the Plan: The Contractor shall designate a party (or parties) responsible for implementing the Construction Waste Management Plan. This party (or parties) shall explain to Contractor's and Subcontractor's construction personnel, the Plan's goals and methods for achieving those goals.

1.8 SPECIAL PROGRAMS:

A. The Contractor shall be responsible for final implementation of programs involving tax credits, rebates, or similar incentives related to recycling, if applicable to the Project. Revenues or other savings obtained for recycling or returns shall accrue to the Contractor.

B. The Contractor shall be responsible for obtaining information packets related to the special programs prior to commencing Work.

C. The Contractor shall document work methods, recycled materials, etc., as required for the tax credits, rebates, or other savings described above.

END OF SECTION

SECTION 01600: MATERIALS AND EQUIPMENT

1. SCOPE:

   A. Index:

      1. Scope
      2. Materials
      3. Equipment
      4. Hazardous Material Requirements
      5. Material Storage
      6. Protection
      7. Revisions

2. MATERIALS:

   A. Furnish materials of the type, qualities, and characteristics specified. The specification of a trade name and catalog number is intended to establish quality, type, character, and operating characteristics of the material required. Materials by other manufacturers of equal specifications will be accepted, excepting as may be specifically stated otherwise.

   B. Materials shall be delivered adequately protected, in merchantable condition, and in original unbroken packages if normally packaged. They shall be stored and handled so as to protect and maintain their merchantable condition.

   C. The Commissioner of Public Works or his representative shall have the right to reject material not in compliance with the project manual, as well as damaged material, and the contractor shall remove such material from the construction site when and as directed.

3. EQUIPMENT:

   A. Internal combustion engine and compressor shall be equipped with mufflers to reduce noise to a minimum and shall not be operated in enclosed areas without adequate ventilation.

   B. All materials and work procedures used shall be in accordance with all air pollution control regulations in effect at the work site.

4. HAZARDOUS MATERIAL REQUIREMENTS:

   A. The requirements set forth in the OSHA Hazard Communication Standard, 29CFR19101.1200, U.S. Environmental Protection Agency (EPA), and Wisconsin Department of Natural Resources in the Wisconsin Administrative Code NR600, shall be met by each on-site contractor.

      1. Material Safety Data Sheets (M.S.D.S.):

         a. All contractors, which may/may not include the City of Milwaukee, shall provide the M.S.D.S. for all hazardous chemicals to which any person may be exposed at the work site.

         b. A master list will be kept in the office of the Project Supervisor/Construction Manager and updated as materials are delivered.

2. Container Labeling:

Each container of hazardous material at the work site shall be clearly labeled with:

a.) Identity of the hazardous chemical(s).

b.) Appropriate hazard warning(s).

c.) Name and address of the manufacturer.

B. The City of Milwaukee reserves the right to stop the work of a contractor if compliance with OSHA regulations is inadequate. Work will not proceed until all applicable safety and health procedures are implemented by the contractor.

5. MATERIAL STORAGE:

A. The storage areas shall be kept in good order and free of all rubbish and debris.

B. Coordinate the delivery and storage of all materials and equipment with the FACILITIES DEVELOPMENT AND MANAGEMENT SECTION Project Inspector.

C. Designate receiving/storage areas for incoming products so that they are delivered according to installation schedule and placed convenient to work area in order to minimize waste due to excessive materials handling and misapplication.

D. Store and protect products in accordance with manufacturer's instructions.

E. Store with seals and labels intact and legible.

F. Store sensitive products in weather tight, climate controlled, enclosures in an environment favorable to product.

G. For exterior storage of fabricated products, place on sloped supports above ground.

H. Cover products subject to deterioration with impervious sheet covering. Provide ventilation to prevent condensation and degradation of products.

I. Prevent contact with material that may cause corrosion, discoloration, or staining.

J. Provide equipment and personnel to store products by methods to prevent soiling, disfigurement, or damage.

K. Arrange storage of products to permit access for inspection. Periodically inspect to verify products are undamaged and are maintained in acceptable condition.

6. PROTECTION:

A. The premises and the work shall be adequately protected from damage from the commencement of work to the date of final acceptance.

B. All construction work and traffic shall remain within the construction area.

C. All damage shall be corrected or repaired by the contractor or contractors causing same at his or their own expense.

D. All open pipes, pipe threads, fittings, and insulation must be protected during construction.

7. REVISIONS:

The right is reserved to make modifications to a reasonable extent as building conditions may require, or as may be required to conform to code rulings, or manufacturer's standards without extra cost to the City.

END OF SECTION

SECTION 01700: CLEANING AND PROJECT CLOSE-OUT

1. SCOPE:

A. Index:

1. Scope
2. General
3. Safety Cleaning
4. Progress Cleaning
5. Disposal
6. Final Cleaning
7. Charges
8. Record Drawings
9. Operating Instructions & Maintenance Manuals
10. Guarantees

2. GENERAL:

Article 2.5.4 of the General Requirements of City of Milwaukee Department of Public Works shall be supplemented as specified hereinafter.

3. SAFETY CLEANING:

Safety cleaning: Each contractor is responsible for safety cleaning, which includes but is not limited to the following:

A. Keep work areas, driveways, parking areas, ramps, stairs, free of debris and scrap.

B. Form and scrap lumber shall have nails withdrawn or bent over and lumber shall be stacked or removed.

C. Remove spills of oil, grease, or other liquids immediately.

D. Hazardous material shall be handled in accordance with Section 01600. Each container of hazardous material at the work site shall be clearly labeled with:

a. Identity of the hazardous chemical(s)
b. Appropriate hazard warning(s).

4. PROGRESS CLEANING:

A. Prime Contractor and subcontractor shall remove his rubbish and debris from building site promptly upon its accumulation, and prior to the contractor's regular Friday general clean up. Contractor shall perform broom cleaning of all appropriate surfaces each Friday afternoon.

B. Combustible waste shall be stored in fire resistive containers and disposed of regularly.

C. Oily, flammable or hazardous wastes such as caustics, acids, harmful dusts, etc., shall be stored in appropriate covered containers.

D. All solvents and cleaners used on this project must be rated as containing low or no volatile organic compounds (VOC's).

5. DISPOSAL:

A. No burning of rubbish or debris will be allowed at site. No rubbish shall be thrown through opening or from heights without proper protection. Where dust will be generated or flying debris is likely to occur, provide dust tight chutes or other means to control dust.

B. Containers: Contractor shall provide mobile industrial type waste containers in the number and size required, placed at adequate locations to handle debris or provide other methods of disposing of debris.

C. Oil, flammable or hazardous wastes such as, but not limited to, caustics, acids, harmful dusts, etc., shall be placed in properly marked containers as necessary and disposed of at a site designed for such wastes.

6. FINAL CLEANING:

A. Immediately prior to substantial completion.

B. Contractors shall expedite or perform thorough cleaning, sweeping, washing and polishing of work to remove from work and equipment provided under his contract, all foreign matter, spots and soil, so as to put all such work and equipment, including finishes, in a complete and finished condition ready for acceptance and use intended.

C. The contractor is responsible for final sweeping and dusting not covered by other subcontractors. This general cleaning shall include all areas and floors of the building, including the site outside the building.

D. All solvents and cleaners used on this project must be rated as containing low or no volatile organic compounds (VOC's).

7. CHARGES:

A. If prime contractor does not remove rubbish or clean building as specified above, the owner reserves right to have work done by others at contractor's expense.

B. Employees or contracted services of the owner who are required to clean up any rubbish or to sweep any floors because prime contractor failed to do so will record all hours involved to complete such work. The cost incurred by the owner for this special cleaning and sweep-up work shall be charged against the contract price of the contractor as determined by owner.

8. RECORD DRAWINGS:

A. After the completion of work and prior to final payment, the mechanical and electrical contractors shall provide FACILITIES DEVELOPMENT AND MANAGEMENT SECTION with three (3) marked up sets of prints showing all changes or variations from contract drawings, and not specified on change order drawings theretofore issued. Contractors providing buried or concealed piping, conduit, or similar items shall locate such items by dimensions and elevations.

B. Other contractors shall provide one (1) marked up set of prints showing all changes or variations from contract drawings.

C. Drawings shall show complete layout of revised piping, equipment, etc., as actually installed.

9. OPERATING INSTRUCTIONS AND MAINTENANCE MANUALS:

A. The contractor shall, upon completion of all work, furnish the necessary skilled labor to instruct City personnel in the operation, adjustment, and maintenance of all equipment furnished.

B. At termination of work, the contractor shall submit maintenance and operating manuals presenting full details of care and maintenance and operation of mechanical and electrical equipment of every nature. See specific requirements in relevant sections as applicable.

C. The manual shall include manufacturer's instructions for maintenance and operation and shall be completely indexed, including the spare parts list. See specific requirements in relevant sections.

D. Submit three (3) final copies in hard bound cover to FACILITIES DEVELOPMENT AND MANAGEMENT SECTION.

E. The contractor shall allow for 3- 1 hour training sessions for City maintenance personnel on all equipment and controls installed under this contract.

10. GUARANTEES:

A. Each contractor shall guarantee to replace or repair promptly at his own expense, as directed by the Commissioner of Public Works or his agent, all workmanship or materials in which defects may develop within one (1) year from the date of final acceptance of his work. This guarantee includes all damage done to the City due to faulty equipment, poor installation or poor construction.

B. Guarantee periods other than the one year time period are indicated in specific specification sections.

END OF SECTION

SECTION 06100: ROUGH CARPENTRY

1. SCOPE: Installation of miscellaneous wood framing. furring, blocking, cants and other items not specifically described as being installed under other sections. This section covers everything necessary for or incidental to executing and completing the rough carpentry and related work, unless specifically excluded by note on drawings or in these specifications.

   A. Index:

      1. Scope
      2. Product Handling
      3. Job Conditions
      4. Materials
      5. Execution
      6. Clean Up

   B. Related Work Specified Elsewhere:

      1. Built-Up Asphalt Roofing Section 075110
      2. Sealant Section 079100

2. PRODUCT HANDLING:

   A. Protect lumber and keep under cover both in transit and at job site. Protect from dampness. Stack framing lumber and plywood to insure proper air circulation. Locate and stack on well-drained areas. Support minimum of 6 inches above grade and cover.

   B. Use all means necessary to protect the installed work and materials of other trades.

3. JOB CONDITIONS:

   A. Field verify all dimensions prior to construction. Notify Architect of discrepancies prior to construction.

   B. Damaged material shall not be accepted.

4. MATERIALS:

   A. Lumber shall be sound, seasoned, free of warps, shall have maximum moisture content of 19% at time of delivery to job site, shall conform to Voluntary Products Standard PS20-70 and Western Wood Products Association and shall be grade marked.

      1. Plates, studs, rough bucks, and nailers 1 1/2" thick and thicker: WP No. 2, Douglas Fir, Hem Fir, West Coast Hemlock, or Southern Pine.

      2. Grounds, blocking, nailers less than 1 1/2" thick: WP No. 3, Douglas Fir, Hemlock Fir, West Coast Hemlock, or White Pine.

      3. Blocking, cants, etc., used on the roof or in contact with moisture shall be pressure treated in accordance with the Standard Specification of the American Wood Preservers Association and conform to Fed. Spec. TT-W-550, TT-W-535, TT-W-571, AWPB LP-2 and American Wood Preservers Institute P-5 Standard and C2 treatment for normal exposure. Preservative shall leave wood fungus resistant.

4. Wood Treatment:

   a. Surfaces of lumber which will remain in contact with masonry, concrete or steel on exterior of building, and wood on interior in contact with exterior walls, after fitting and before installation shall receive 2 flood coats, or shall be given plant or job site 3 minute dip method wood preservative treatment using water repellant preservatives containing 5 percent chlorinated phenols of type that fulfill minimum requirements of National Woodwork Manufacturers Association Specification NWMA Minimum Standards for Water Repellant Preservatives for Millwork. Preservatives containing chromate zinc chloride, cuprinal, creosote and/or copper napthanate are not permitted.

   b. Preservative treatment for wood exposed to view shall be of a type that can be readily painted.

B. Adhesive:

Adhesive shall be "Sta-Stuck SS-400" construction and decking adhesive as manufactured by the Radford Company.

C. Plywood which will not be a finished surface shall be American Plywood Association Exterior Grade C-C, sanded one side. Roof sheathing - 4'-0" x 8'-0" x 3/4" APA rated sheathing with exterior glue.

D. Rough Hardware:

1. Anchors, strips and hangers shall be galvanized and attached to woodwork with galvanized coated or plated fasteners.

2. Machine bolts and nuts shall conform to ASTM A-307 and be galvanized or plated.

3. Expansion bolts shall be split shield or wedge type.

4. Nails shall be common, and conform to Fed. Spec. FF-N-1-1. Use galvanized or plated nails at exterior locations.

5. EXECUTION:

A. Surface Conditions:

1. Prior to the work of this section, carefully inspect the installed work of all other trades and verify that all such work is complete to the point where this installation may commence.

2. In the event of discrepancies, notify the Architect, and do not proceed with installation of this work until the discrepancies have been resolved.

3. Schedule the work of this section to cooperate with the work of other trades to avoid any time delays.

B. Fastening:

1. Bolt heads and nuts (galvanized) bearing on wood shall have standard (galvanized) washers. Counter sink nuts and washers where required.

2. Generally use fasteners as follows:

   a. Galvanized 3/4" diameter anchor bolts or expansion bolts spaced 2'-8" o.c. for attaching to masonry or concrete.

   b. 16d or 20d nails for fastening 2" nominal lumber and 30d or 40d nails for fastening thicker lumber.

   c. Treated wood requires hot dip galvanized fasteners.

   d. Where nailers or blocking occur with steel framing they shall be bolted to steel work. Cope edges to fit around steel for tight bearing.

3. Fasteners for wood grounds, furring, and similar items to masonry and concrete shall be toggle bolts, tapcons, lag screws in expansion shield, or screws in fiber inserts.

C. Installation - General:

1. All rough carpentry shall produce joints true, tight and well secured with all members assembled in accordance with the drawings and with all pertinent codes and regulations.

2. Provide furring, nailers, and blocking for drywall, roofing and where same is shown or required.

3. Generally use fasteners as follows:

   a. 1/2" diameter anchor bolts or expansion bolts spaced 4'-0" o.c. for attaching to masonry or concrete.

   b. 16d or 20d nails for fastening 2" nominal lumber and 30d or 40d nails for fastening thicker lumber.

   c. Treated wood requires hot dip galvanized fasteners.

4. Fasteners for wood grounds, furring, and similar items to masonry and concrete shall be toggle bolts, tapcons, lag screws in expansion shield, or screws in fiber inserts.

D. Roof Sheathing:

   a. Install with long dimensions across supports and with panels continuous over two or more spans.

   b. Panel edge joints shall occur over framing. Allow 1/16" space at ends and edges.

   c. Nail at 6" o.c. along supported panel edges and 12" o.c. at intermediate supports with 8d nails.

6. CLEAN UP:

A. Keep the premises in a neat, safe, and orderly condition at all times during execution of this work, free from accumulation of sawdust, cut-ends and debris.

1. Remove debris and refuse from job site and legally dispose of same.

2. Upon completion of the work thoroughly clean all surfaces.

END OF SECTION

SECTION 075110 - BUILT-UP ASPHALT ROOFING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

A. This Section includes the following summary of work to be performed on designated roof areas:

1. Removal and disposal of the existing roof system components down to the structural concrete deck or existing vapor barrier. If the existing vapor barrier is firmly bonded to the deck, it may remain in place.
2. Clean and prime the existing substrate with asphalt based primer.
3. Install a new vapor barrier and insulation envelope as specified with SEBS rubberized / modified asphalt.
4. Install new tapered insulation layers as specified.
5. Install new retrofit drain assemblies where required.
6. Install new Base + Three ply built up roof system with SEBS rubberized / modified asphalt.
7. Install specified flashings adhered with SEBS rubberized / modified asphalt, mastics and aluminum coatings.
8. Install new gravel surfacing (450 lbs per 100 square feet) adhered in Type III Asphalt applied at a rate of 60 lbs per 100 square feet.
9. Install required sheet metal components and projection flashings.

B. Related Sections include the following:
1. Division 6 Section "Rough Carpentry" for wood nailers, cants, curbs, and blocking.
2. Division 7 Section "Sheet Metal Flashing and Coping System" for metal roof penetration flashings, flashings, and counterflashings.

C. Unit Prices: Refer to Division 1 Section "Unit Prices" for description of Work in this Section affected by unit prices.

1.3 DEFINITIONS

A. Roofing Terminology: Refer to ASTM D 1079 and glossary of NRCA's "The NRCA Roofing and Waterproofing Manual" for definition of terms related to roofing work in this Section.

B. Hot Roofing Asphalt: Roofing asphalt heated to its equiviscous temperature, the temperature at which its viscosity is 125 centipoise for mopping application and 75 centipoise for mechanical application, within a range of plus or minus 25 deg F (14 deg C), measured at the mop cart or mechanical spreader immediately before application.

1.4 PERFORMANCE REQUIREMENTS

A. General: Provide installed roofing membrane and base flashings that remain watertight; do not permit the passage of water; and resist specified uplift pressures, thermally induced movement, and exposure to weather without failure.

B. Material Compatibility: Provide roofing materials that are compatible with one another under conditions of service and application required, as demonstrated by roofing manufacturer based on testing and field experience.

C. FMG Listing: Provide roofing membrane, base flashings, and component materials that comply with requirements in FMG 4450 and FMG 4470 as part of a roofing system and that are listed in FMG's "Approval Guide" for Class 1 or noncombustible construction, as applicable. Identify materials with FMG markings.

1. Fire/Windstorm Classification: Class 1A-90.

1.5 SUBMITTALS

A. Product Data: For each type of product indicated.

B. Shop Drawings: For roofing system. Include plans, elevations, sections, details, and attachments to other Work.

1. Base flashings, cants, and membrane terminations.

C. Samples for Verification: For the following products:

1. 12-by-8-inch (300-by-300-mm) square of base sheet ply sheet.
2. 12-by-8-inch (300-by-300-mm) square of flashing sheet, of color specified.
3. Pull sample of rubberized asphalt material specified.

D. Installer Certificates: Signed by roofing system manufacturer certifying that Installer is approved, authorized, or licensed by manufacturer to install roofing system.

E. Manufacturer Certificates: Signed by roofing manufacturer certifying that roofing system complies with requirements specified in "Performance Requirements" Article.

1. Submit evidence of meeting performance requirements.

F. Qualification Data: For Installer and manufacturer.

G. Product Test Reports: Based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified testing agency, for components of roofing system.

1. Indicate that bulk roofing asphalt materials delivered to Project comply with requirements. Include quantity and statistical and descriptive data for each product. Submit certificate with each load before it is used.
2. Include continuous log showing time and temperature for each load of bulk asphalt, indicating date obtained from manufacturer, where held, and how transported before final heating and application on roof.

H. Research/Evaluation Reports: For components of roofing system.

I. Maintenance Data: For roofing system to include in maintenance manuals.

J. Warranties: Special warranties specified in this Section.

K. Inspection Report: Copy of roofing system manufacturer's inspection report of completed roofing installation.

1.6 QUALITY ASSURANCE

A. Installer Qualifications: A qualified firm that is approved, authorized, or licensed by roofing system manufacturer to install manufacturer's product and that is eligible to receive manufacturer's warranty.

B. Technical Inspector Qualifications: As part of the project warranty, the Roofing Contractor will engage a qualified manufacturer's technical representative for a minimum of 1 day per 2,000 to perform roof specification review, inspections of the work in progress and to provide reports to the Owner. The Technical Inspector shall have a minimum of 10 years experience with the particular roof system installation and provide a non-sales function for the primary manufacturer.

C. If the manufacturer doesn't employ a qualified technical inspector, an engineering firm may be enlisted by the primary manufacturer at their expense to provide technical installation inspections for equal assistance / inspection time at the approval of the Owner.

D. Manufacturer Qualifications: Proof of ISO 9001 quality certification for roof manufacturer providing warranty for the roof system and components.

E. Testing Agency Qualifications: An independent testing agency with the experience and capability to conduct the testing indicated, as documented according to ASTM E 548.

F. Source Limitations: Obtain components for roofing system from or approved by roofing system manufacturer providing the roof warranty.

G. Fire-Test-Response Characteristics: Provide roofing materials with the fire-test-response characteristics indicated as determined by testing identical products per test method below by UL, FMG, or another testing and inspecting agency acceptable to authorities having jurisdiction. Materials shall be identified with appropriate markings of applicable testing and inspecting agency.

1. Exterior Fire-Test Exposure: Class A; ASTM E 108, for application and roof slopes indicated.
2. Fire-Resistance Ratings: ASTM E 119, for fire-resistance-rated roof assemblies of which roofing system is a part.

H. Preinstallation Conference: Conduct conference at Project site. Comply with requirements in Division 1 Section "Project Management and Coordination." Review methods and procedures related to roofing system including, but not limited to, the following:

1. Meet with Owner, roofing Installer, roofing system manufacturer's representative, , and installers whose work interfaces with or affects roofing including installers of roof accessories and roof-mounted equipment.
2. Review methods and procedures related to roofing installation, including manufacturer's written instructions.
3. Review and finalize construction schedule and verify availability of materials, Installer's personnel, equipment, and facilities needed to make progress and avoid delays.

4. Examine deck substrate conditions and finishes for compliance with requirements, including flatness and fastening.
5. Review structural loading limitations of roof deck during and after roofing.
6. Review base flashings, special roofing details, roof drainage, roof penetrations, equipment curbs, and condition of other construction that will affect roofing system.
7. Review governing regulations and requirements for insurance and certificates if applicable.
8. Review temporary protection requirements for roofing system during and after installation.
9. Review roof observation and repair procedures after roofing installation.

1.7 DELIVERY, STORAGE, AND HANDLING

A. Deliver roofing materials to Project site in original containers with seals unbroken and labeled with manufacturer's name, product brand name and type, date of manufacture, and directions for storage.

B. Store liquid materials in their original undamaged containers in a clean, dry, protected location and within the temperature range required by roofing system manufacturer. Protect stored liquid material from direct sunlight.

1. Discard and legally dispose of liquid material that cannot be applied within its stated shelf life.

C. Protect roof insulation materials from physical damage and from deterioration by sunlight, moisture, soiling, and other sources. Store in a dry location. Comply with insulation manufacturer's written instructions for handling, storing, and protecting during installation.

D. Handle and store roofing materials and place equipment in a manner to avoid permanent deflection of deck.

1.8 PROJECT CONDITIONS

A. Weather Limitations: Proceed with installation only when existing and forecasted weather conditions permit roofing system to be installed according to manufacturer's written instructions and warranty requirements.

1.9 WARRANTY

A. Special Warranty: Manufacturer's standard form, without monetary limitation, in which manufacturer agrees to repair or replace components of roofing system that fail in materials or workmanship within specified warranty period. Failure includes roof leaks.

1. Special warranty includes roofing membrane, base flashings, roofing membrane accessories, roof insulation, fasteners, cover boards and other components of roofing system.
2. Warranty Period: 20 years from date of Substantial Completion with no dollar limit.
3. Peak Wind Coverage: Up to 74 miles per hour

B. Special Project Warranty: Submit roofing Installer's warranty, on warranty form at end of this Section, signed by Installer, covering Work of this Section, including all components of roofing system such as roofing membrane, base flashing, roof insulation, fasteners, cover boards,

substrate boards, vapor retarders, roof pavers, and walkway products, for the following warranty period:

1. Warranty Period: Two years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following: The "Basis of Design" specification is based upon TREMCO, Inc. materials and roof systems, Beachwood, OH.

B. The intent of the specification package is to establish minimum acceptable quality and performance standards for the finished roof replacement project. Subject to compliance with all requirements, any primary manufacturer meeting or exceeding the specification design standard is encouraged to pursue the project.

C. Additional Manufacturers:
1. The Garland Company, Cleveland, OH
2. Barrett Products, Millington, NJ
3. Firestone Building Products, Carmel, Ind

D. In other Part 2 articles where titles below introduce lists, the following requirements apply for product selection:
1. Products: Subject to compliance with requirements, provide one of the products specified.

2.2 FINISHED ROOF MEMBRANE PERFORMANCE REQUIREMENTS

A. BUILT UP ROOF SYSTEM (Base + Three (3) ply BUR Membrane)

Property	Typical Value	Test Method
Tensile Strength: @ 0 deg F	484 lbf/in MD	ASTM D 2523
	428 lbf/in XMD	ASTM D 2523

2.3 BASE-SHEET MATERIALS

1 Base Sheet (Roof Membrane and Vapor Barrier): Trilaminate reinforced ply sheet, complying with ASTM D 4601-91; ASTM 228-90A and ASTM 146-90 with the following properties:

a. Thickness: 1.2 mm
b. Breaking strength: 220 lbf/in(38.5 kN/M) MD. 235 lbf/in (41.1 kN/m) XMD.
c. Elongation: 6.5% MD/XMD.
d. Tear Strength: 345 lbf (1534 N) MD. 330 lbf (1467 N) XMD minimum.
e. Mass of desaturated polyester/glass/polyester mat, min.: 3.5 lb/100ft (172 g/m^2).
f. Recycled Content: Minimum 10%
g. Asphalt: 10.0 lb/100 ft (485g/m^2) minimum.

2.4 ROOFING MEMBRANE PLIES

A. Ply Sheet: ASTM D 2178, Type VI, asphalt-impregnated, glass-fiber felt.

2.5 FLASHING MATERIALS

A. Backer Sheet: ASTM D 2178, Type VI, asphalt-impregnated, glass-fiber felt.

B. Flashing Sheet: Elastomeric sheeting blend of EPDM and SBR thermoset elastomers. Sheet must be reinforced with polyester woven scrim.

C. Glass-Fiber Fabric: Woven glass cloth, treated with asphalt, complying with ASTM D 1668, Type I.

D. Flashing Adhesive:
   1. Hot Applied - SEBS modified rubberized asphalt.
   2. Cold Applied (3rd Floor Roof Only) – Single component, bitumen modified, moisture curing, polyurethane mastic adhesive.

E. Stripping Ply: 6" Polyester woven felt or 6" fiberglass woven mesh.

F. Termination Bar Tape: Flexible, Butyl based sealant tape. 1/8" thick X 1"

G. Termination Bar Sealant: Polyurethane sealant.

H. Flashing Surfacing: Fibrated aluminum coating meeting requirements for ASTM 2824, Type III

2.6 ASPHALT MATERIALS

A. Asphalt Primer: ASTM D 41.

B. Roofing Asphalt – insulation adhesive, final surfacing: ASTM D 312, Type III. – steep asphalt.

C. Polymer Modified Roofing Asphalt – Vapor Barrier, 4 Ply Membrane and Perimeter Base Flashings: SEBS modified rubberized asphalt.

2.7 AUXILIARY ROOFING MEMBRANE MATERIALS

A. General: Auxiliary materials recommended by roofing system manufacturer for intended use and compatible with built-up roofing.

B. Asphalt Roofing Cement: ASTM D 4586, asbestos free, of consistency required by roofing system manufacturer for application.

C. Mastic Sealant: Polyisobutylene, plain or modified bitumen, nonhardening, nonmigrating, nonskinning, and nondrying.

D. Fasteners: Factory-coated steel fasteners and metal or plastic plates meeting corrosion-resistance provisions in FM 4470; designed for fastening roofing membrane components to substrate; tested by manufacturer for required pullout strength; and acceptable to roofing system manufacturer.

E. Metal Flashing Sheet: Metal flashing sheet is specified in Division 7 Section "Sheet Metal Flashing and Trim."

F. Miscellaneous Accessories: Provide miscellaneous accessories recommended by roofing system manufacturer.

G. Final Gravel Surfacing: 3/8" to 5/8" gravel complying with ASTM D 1863.

2.8 ROOF INSULATION

A. General: Provide preformed roof insulation boards that comply with requirements and referenced standards, selected from manufacturer's standard sizes and of thicknesses indicated.

B. Polyisocyanurate Board Insulation: ASTM C 1289, Type II, felt or glass-fiber mat facer on both major surfaces.

1. Manufacturers: As recommended by Roof System Manufacturer / Warranty Provider

C. Cellulosic-Fiber Board Insulation: ASTM C 208, Type II, Grade 1, 6 side asphalt coated, fibrous-felted wood fiber or other cellulosic-fiber and water-resistant binders, asphalt impregnated, chemically treated for deterioration.

1. Manufacturers: As recommended by Roof System Manufacturer / Warranty Provider

D. Provide preformed crickets, tapered edge strips, and other insulation shapes where indicated for sloping to drain. Fabricate to slopes indicated.

E. Polyisocyanurate Insulation Board: Factory tapered boards sloping at 1/8" per foot; minimum thickness at the edge of the drain sum shall be 2.0".

F. Tapered Insulation Sumps: Minimum 8' x 8' factory tapered drain sumps using polyisocyanurate or in combination with wood fiberboard roofing insulation. Drain sumps shall slope at ¼" per foot. Note: 2nd Floor Roof shall require 4' x 4' drain sumps.

2.9 INSULATION ACCESSORIES

A. General: Roof insulation accessories recommended by insulation manufacturer for intended use and compatible with membrane roofing.

B. Insulation Cant Strips: ASTM C 208, Type II, Grade 1, cellulosic-fiber insulation board.

C. Tapered wedge boards: ASTM C 208, Type II, Grade 1, cellulosic-fiber tapered insulation board.

D. Wood Nailer Strips: Comply with requirements in Division 6 Section " Rough Carpentry."

2.10 WALKWAYS

A. Walkway Pads: Mineral-granule-surfaced, reinforced asphaltic composition, slip-resisting pads, manufactured as a traffic pad for foot traffic and acceptable to roofing system manufacturer, 1/2 inch (13 mm) thick, minimum.

1. Pad Size: 3 feet x 4 feet.

2. Walkpads are to be located at all doors / access hatches and at access panels for mechanical units.

PART 3 - EXECUTION

3.1 EXAMINATION

A. Examine substrates, areas, and conditions, with Installer present, for compliance with the following requirements and other conditions affecting performance of roofing system:

1. Verify that roof openings and penetrations are in place and set and braced and that roof drains are securely clamped in place.
2. Verify that wood cants, blocking, curbs, and nailers are securely anchored to roof deck at penetrations and terminations and that nailers match thicknesses of insulation.

3. Verify that deck is securely fastened with no projecting fasteners and with no adjacent units in excess of 1/16 inch (1.6 mm) out of plane relative to adjoining deck.
4. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

A. Clean substrate of dust, debris, moisture, and other substances detrimental to roofing installation according to roofing system manufacturer's written instructions. Remove sharp projections.

B. Prevent materials from entering and clogging roof drains and conductors and from spilling or migrating onto surfaces of other construction. Remove roof-drain plugs when no work is taking place or when rain is forecast.

C. Apply asphalt based primer to all horizontal and vertical substrates that will be receiving roofing materials.

3.3 VAPOR BARRIER INSTALLATION

A. Install one lapped course of base sheet, extending sheet over and terminating beyond cants. Attach base sheet as follows:
1. Adhere to substrate in a solid mopping of hot SEBS modified asphalt.
2. Seal all projections with asphalt mastic and reinforcement mesh.

B. Install an envelope strip of base sheet that shall extend from the horizontal vapor barrier vertically and sealed onto the top of the roof insulation a minimum of 12"
1. Adhere to substrate in a solid mopping of hot SEBS modified asphalt.

3.3 INSULATION INSTALLATION

A. Coordinate installing roofing system components so insulation is not exposed to precipitation or left exposed at the end of the workday.

B. Comply with roofing system manufacturer's written instructions for installing roof insulation.

C. Insulation Cant Strips: Install and secure preformed 45-degree wood cant strips at junctures of built-up roofing membrane system with vertical surfaces or angle changes greater than 45 degrees.

D. Install insulation with long joints of insulation in a continuous straight line with end joints staggered between rows, abutting edges and ends between boards. Fill gaps exceeding 1/4 inch (6 mm) with insulation.

1. Cut and fit insulation within 1/4 inch (6 mm) of nailers, projections, and penetrations.

E. Trim surface of insulation where necessary at roof drains so completed surface is flush and does not restrict flow of water.

F. Install cover boards over insulation with long joints in continuous straight lines with end joints staggered between rows. Stagger joints from joints in insulation below a minimum of 6 inches (150 mm) in each direction.
1. Apply hot roofing asphalt to underside and immediately bond cover board to substrate.

3.4 ROOFING MEMBRANE INSTALLATION, GENERAL

A. Install built-up roofing membrane system according to roofing system manufacturer's written instructions and applicable recommendations of ARMA/NRCA's "Quality Control Guidelines for the Application of Built-up Roofing."

B. Start installation of built-up roofing membrane in presence of roofing system manufacturer's technical personnel.

C. Cooperate with testing and inspecting agencies engaged or required to perform services for installing built-up roofing system.

D. Coordinate installing roofing system components so insulation and roofing membrane sheets are not exposed to precipitation or left exposed at the end of the workday or when rain is forecast.

1. Provide tie-offs at end of each day's work to cover exposed roofing membrane sheets and insulation with a course of coated felt set in roofing cement or hot roofing asphalt with joints and edges sealed.
2. Complete terminations and base flashings and provide temporary seals to prevent water from entering completed sections of roofing system.
3. Remove and discard temporary seals before beginning work on adjoining roofing.

E. Asphalt Heating: Heat roofing asphalt and apply within plus or minus 25 deg F (14 deg C) of equiviscous temperature unless otherwise required by roofing system manufacturer. Do not raise roofing asphalt temperature above equiviscous temperature range more than one hour before time of application. Do not exceed roofing asphalt manufacturer's recommended temperature limits during roofing asphalt heating. Do not heat roofing asphalt within 25 deg F (14 deg C) of flash point. Discard roofing asphalt maintained at a temperature exceeding finished blowing temperature for more than 4 hours.

F. Asphalt Heating: Heat and apply SEBS-modified roofing asphalt according to roofing system manufacturer's written instructions.

G. Substrate-Joint Penetrations: Prevent roofing asphalt from penetrating substrate joints, entering building, or damaging roofing system components or adjacent building construction.

3.5 ROOFING MEMBRANE INSTALLATION

A. Install one lapped course of base sheet, extending sheet over and terminating beyond cants. Attach base sheet as follows:
   1. Adhere to substrate in a solid mopping of hot SEBS modified asphalt.

B. Install three ply sheets starting at low point of roofing system. Align ply sheets without stretching. Shingle side laps of ply sheets uniformly to achieve required number of plies throughout thickness of roofing membrane. Shingle in direction to shed water. Extend ply sheets over and terminate beyond cants.

   1. Embed each ply sheet in a solid mopping of hot rubberized asphalt applied at rate required by roofing system manufacturer, to form a uniform membrane without ply sheets touching.

C. Gravel Surfacing: Promptly after installing and testing roofing membrane, base flashing, and stripping, coat roof surface with Type III asphalt applied at a rate of approximately 60 lbs per 100 square feet. Immediately following the flood coat of the roof, broadcast new gravel into the flood coat asphalt at a rate of 450 – 500 lbs per 100 square feet.

3.6 FLASHING AND STRIPPING INSTALLATION

A. Install base flashing over cant strips and other sloping and vertical surfaces, at roof edges, and at penetrations through roof, and secure to substrates according to roofing system manufacturer's written instructions and as follows:

   1. Prime substrates with asphalt primer if required by roofing system manufacturer.
   2. Backer Sheet Application: Install backer sheet and adhere to substrate in a solid mopping of hot roofing asphalt or polyurethane mastic adhesive.
   3. Flashing Sheet Application: Adhere flashing sheet to substrate in a solid mopping of hot rubberized asphalt applied at not less than 425 deg F (218 deg C). Apply hot rubberized asphalt or polyurethane adhesive to back of flashing sheet and substrate surface if recommended by roofing system manufacturer.

B. Extend base flashing up walls or parapets a minimum of 8 inches (200 mm) above roofing membrane and 4 inches (100 mm) onto field of roofing membrane.

C. Mechanically fasten top of base flashing securely at terminations and perimeter of roofing. Utilize the aluminum termination bar and masonry anchors.

   1. Install butyl tape between flashing and wall, compressed by the termination bar.

   2. Seal termination bars of the base flashing with polyurethane sealant

D. Install stripping, according to roofing system manufacturer's written instructions, where metal flanges and edgings are set on built-up roofing.

   1. Flashing-Sheet Stripping: Install flashing-sheet stripping in a continuous coating of asphalt roofing cement or in a solid mopping of hot roofing asphalt applied at not less

than 425 deg F (218 deg C), reinforced with 6" polyester felt, and extend onto roofing membrane.

E. Roof Drains: Set 30-by-30-inch (760-by-760-mm) metal flashing in bed of asphalt roofing cement on completed roofing membrane. Cover metal flashing with stripping and extend a minimum of 4 inches (100 mm) beyond edge of metal flashing onto field of roofing membrane. Clamp roofing membrane, metal flashing, and stripping into roof-drain clamping ring.

1. Install flashing-sheet stripping by same method as installing base flashing.

3.7 COATING INSTALLATION

A. Apply coatings to base flashings and projections according to manufacturer's written instructions, by roller, brush, or other suitable application method.

3.8 WALKWAY INSTALLATION

A. Walkway Pads: Install walkway pads using units of size indicated or, if not indicated, of manufacturer's standard size according to walkway pad manufacturer's written instructions.

1. Sweep away loose aggregate surfacing and set walkway pads in clumps of asphalt mastic in the corners of the walkway pad.

3.9 FIELD QUALITY CONTROL

A. Testing Agency: Owner reserves the right to engage a qualified independent testing and inspecting agency to perform roof tests and inspections and to prepare test reports.

B. Test Cuts: Before flood coating and surfacing built-up roofing membrane, the Owner reserves the right to test specimens will be removed to evaluate problems observed during quality-assurance inspections of roofing membrane as follows:

1. Approximate quantities of components within roofing membrane will be determined according to ASTM D 3617.
2. Test specimens will be examined for interply voids according to ASTM D 3617 and to comply with criteria established in Appendix 3 of ARMA/NRCA's "Quality Control Guidelines for the Application of Built-up Roofing."

C. Final Roof Inspection: Arrange for roofing system manufacturer's technical personnel to inspect roofing installation on completion and submit report to Owner.

1. Notify Owner 48 hours in advance of date and time of inspection.

D. Repair or remove and replace components of roofing system where test results or inspections indicate that they do not comply with specified requirements.

E. Additional testing and inspecting, including infrared analysis, at Contractor's expense, will be performed to determine compliance of replaced or additional work with specified requirements.

3.10 PROTECTING AND CLEANING

A. Protect roofing system from damage and wear during remainder of construction period. When remaining construction will not affect or endanger roofing, inspect roofing for deterioration and damage, describing its nature and extent in a written report, with copies to the Owner.

B. Correct deficiencies in or remove roofing system that does not comply with requirements, repair substrates, and repair or reinstall roofing system to a condition free of damage and deterioration at time of Substantial Completion and according to warranty requirements.

C. Clean overspray and spillage from adjacent construction using cleaning agents and procedures recommended by manufacturer of affected construction.

END OF SECTION 075110

SECTION 075910 - MEMBRANE REROOFING PREPARATION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

A. This Section includes the following:

Roof tear-off.
Roof re-cover preparation.
Removal of base flashings.

B. Related Sections include the following:

Division 1 Section "Summary" for use of the premises and phasing requirements.
Division 6 Section "Rough Carpentry" for wood nailers, cants, curbs, and blocking.
Division 7 Section "Built Up Roof" for roofing membrane, base flashings, roof insulation, cover boards, and roofing accessories.
Division 7 Section "Sheet Metal Flashing and Coping Systrem" for metal roof penetration flashings, flashings, and counterflashings.

1.3 MATERIALS OWNERSHIP

A. Except for items or materials indicated to be reused, reinstalled, or otherwise indicated to remain Owner's property, demolished materials shall become Contractor's property and shall be removed from Project site.

1.4 DEFINITIONS

A. Roofing Terminology: Refer to ASTM D 1079 and glossary in NRCA's "The NRCA Roofing and Waterproofing Manual" for definition of terms related to roofing work in this Section.

B. Existing Roofing System: As shown on roof plans and details.

C. Roof Tear-Off: All existing roof membranes, perimeter flashings / sheet metal, roof insulation to expose the structural deck or solid adhered vapor barrier.

D. Remove: Obsolete curbs and equipment and properly dispose of per roof plans for all roof sections.

E. Existing to Remain: Existing items of construction that are not indicated to be removed.

1.5 QUALITY ASSURANCE

A. Installer Qualifications: Installer of new membrane roofing system and approved by warrantor of existing roofing system to work on existing roofing.

B. Regulatory Requirements: Comply with governing EPA notification regulations before beginning membrane roofing removal. Comply with hauling and disposal regulations of authorities having jurisdiction.

C. Preliminary Re-roofing Conference: Conduct conference at Project site to comply with requirements in Division 1 Section "Project Management and Coordination." Review methods and procedures related to roofing system including, but not limited to, the following:

1. Meet with Owner; roofing system manufacturer's representative; roofing Installer including project manager, superintendent, and foreman; and installers whose work interfaces with or affects re-roofing including installers of roof accessories and roof-mounted equipment.
2. Review methods and procedures related to re-roofing preparation, including membrane roofing system manufacturer's written instructions.
3. Review temporary protection requirements for existing roofing system that is to remain, during and after installation.
4. Review roof drainage during each stage of re-roofing and review roof drain plugging and plug removal procedures.
5. Review and finalize construction schedule, and verify availability of materials, Installer's personnel, equipment, and facilities needed to make progress and avoid delays.
6. Review existing deck removal procedures and Owner notifications.
7. Review procedures to determine condition and acceptance of existing deck
8. Review structural loading limitations of deck during re-roofing.
9. Review base flashings, special roofing details, drainage, penetrations, equipment curbs, and condition of other construction that will affect re-roofing.
10. Review HVAC shutdown and sealing of air intakes.
11. Review shutdown of fire-suppression, -protection, and -alarm and -detection systems.
12. Review procedures for asbestos removal or unexpected discovery of asbestos-containing materials.
13. Review governing regulations and requirements for insurance and certificates if applicable.

1.6 PROJECT CONDITIONS

A. Owner will occupy portions of building immediately below re-roofing area. Conduct re-roofing so Owner's operations will not be disrupted. Provide Owner with not less than 48 hours' notice of activities that may affect Owner's operations.

1. Coordinate work activities daily with Owner so Owner can place protective dust or water leakage covers over sensitive equipment or furnishings, shut down HVAC and fire-alarm or -detection equipment if needed, and evacuate occupants from below the work area if desired.
2. Before working over structurally impaired areas of deck, notify Owner to evacuate occupants from below the affected area. Verify that occupants below the work area have been evacuated prior to proceeding with work over the impaired deck area.

B. Protect building to be re-roofed, adjacent buildings, walkways, site improvements, exterior plantings, and landscaping from damage or soiling from re-roofing operations.

C. Construction Drawings and Project Manual for existing roofing system are provided for Contractor's reference. Contractor is responsible for conclusions derived from existing documents.

D. Weather Limitations: Proceed with re-roofing preparation only when existing and forecasted weather conditions permit Work to proceed without water entering into existing roofing system or building. Any damage occurring due to moisture infiltration into existing roof system components, new roof system components or interior building systems requiring replacement or repair will be done so at the sole expense of the contractor.

E. Hazardous Materials: It is expected that hazardous materials such as asbestos-containing materials will be encountered in the Work.

PART 2 - PRODUCTS

2.1 TEMPORARY ROOFING MATERIALS

A. Selection of materials and design of temporary roofing is responsibility of Contractor.

B. Glass-Fiber Felts: 28# Asphalt Coated Fiberglass Base sheet.

C. Asphalt Primer: ASTM D 41.

D. Roofing Asphalt: ASTM D 312, Type III or IV.

PART 3 - EXECUTION

3.1 PREPARATION

A. Coordinate with Owner to shut down air intake equipment in the vicinity of the Work. Cover air intake louvers before proceeding with re-roofing work that could affect indoor air quality or activate smoke detectors in the ductwork.

B. During removal operations, have sufficient and suitable materials on-site to facilitate rapid installation of temporary protection in the event of unexpected rain.

C. Maintain roof drains in functioning condition to ensure roof drainage at end of each workday. Prevent debris from entering or blocking roof drains and conductors. Use roof-drain plugs specifically designed for this purpose. Remove roof-drain plugs at end of each workday, when no work is taking place, or when rain is forecast.

1. If roof drains will be temporarily blocked or unserviceable due to roofing system removal or partial installation of new membrane roofing system, provide alternative drainage method to remove water and eliminate ponding. Do not permit water to enter into or under existing membrane roofing system components that are to remain.

D. Verify that rooftop utilities and service piping have been shut off before commencing Work.

E. Employ, direct, and coordinate a pre-qualified HVAC Mechanical Contractor for ductwork and mechanical unit disconnection / reconnection for all roof replacement projects.

3.2 ROOF TEAR-OFF

A. General: Notify Owner / Project Coordinator each day of extent of roof tear-off proposed.

B. Remove aggregate ballast from roofing membrane, Owner will dispose of ballast rock on site..

C. Roof Tear-Off: Remove existing roofing membrane and other roofing system components to the structural deck or substrate as indicated.

1. Remove roof membrane and accessories
2. Remove existing perimeter flashings and sheet metal components.
3. Remove existing insulations as designated.
4. Remove existing vapor barriers if damaged or not fully bonded to substrate.

3.3 SUBSTRATE PREPARATION

A. Inspect existing deck or substrate after tear-off of existing roofing system.

B. Correct any deficiencies or deck deflections at the approval of the Owner.

3.4 EXISTING BASE FLASHINGS

A. Remove existing base flashings around parapets, curbs, walls, and penetrations.

B. Inspect parapet sheathing or masonry walls for deterioration and damage. If parapet sheathing or masonry walls have deteriorated, immediately notify Owner or Consultant.

C. Inspect existing perimeter wood blocking and replace any damaged or deteriorated wood blocking per Division 6.

D. Add wood blocking to perimeter and curbs if required to accommodate height of insulation and provide minimum flashing heights required. 8" minimum flashing height is required at all projections unless otherwise noted or agreed upon.

3.5 DISPOSAL

A. Collect and place demolished materials in containers. Promptly dispose of demolished materials. Do not allow demolished materials to accumulate on-site.

1. Storage of demolished items or materials on-site will not be permitted unless approved by the Owner.

B. Transport demolished materials from Owner's property and legally dispose of them.

END OF SECTION 075910

SECTION 077100: RETROFIT ROOF DRAINS

1.01 SCOPE: Installation of retrofit roof drains and accessories. This section covers everything necessary for or incidental to executing and completing the retrofit roof drains installation and related work, unless specifically excluded by note on drawings or in these specifications.

1.02 SUMMARY

A. Refer to Section 01011—Project Description—for the scope of work included in this Section.

B. Related Work Specified Elsewhere:

1. Built-Up Asphalt Roofing Section 075110
2. Sealant Section 079100

C. Provide a copy of all applicable Drawings, including Shop Drawings, and Specifications at the site during all work.

D. Follow sequence of work in Summary, Section 01010.

1.03 SYSTEM DESCRIPTION

A. A factory fabricated fixture installed to replace a drain on an existing roof. The fixture is installed from the roof surface and provides a watertight connection to the existing plumbing and roofing system, the fixture is designed so that it may be installed without removing the existing drain body and plumbing.

1.04 REFERENCES

A. ANSI/SPRI RD-1 2004

B. CAN/ULC-C790.4-1996

1.05 SUBMITTALS

A. Submit in accordance with Section 01300- Submittals

B. Provide specification and data sheet.

C. Shop drawings: Show installation layout, including sizes and spacing.

D. Manufacturer's instructions for installation and maintenance.

E. Copy of warranty/warranties specified.

1.06 QUALITY ASSURANCE

A. Applicator Qualifications:

1. Three years successful experience in installation of retrofit drains, including this

product. If required by manufacturer, certification in application of product.

2. Employs persons trained for the application of the specified products.

1.07 DELIVERY, STORAGE AND HANDLING

A. Deliver materials to project site in manufacturer's original packaging, marked with manufacturer's name, product model names and catalog numbers, identification numbers and other related information.

B. Store materials under cover until needed.

1.08 WARRANTY

A. Manufacturer's warranty- to be the material as ordered.

B. Contractor's 3 year installation warranty, to cover labor and materials for properly installed retrofit drains.

PART 2 PRODUCTS

2.01 MANUFACTURERS

A. OMG Roofing Products, 153 Bowles Road, Agawam, Massachusetts 01001. ASD. Tel: (413) 789-0252. Web site: www. Olyfast.com. Email: info@olyfast.com. Or approved equal.

2.02 MATERIALS

A. Drain Body:

1. Manufactured from 11 gauge (.125") spun aluminum.
2. 171/2" diameter flange with a 12" long stem.
3. Flange includes six, 2 ½" long, aluminum studs
4. 4. Depressed sump area.

B. Strainer Dome:

1. Made of cast aluminum.
2. Height – 7.25"
3. Outside base diameter – 9.77".

C. Clamping Ring:

1. Made of cast aluminum/
2. Gravel stop height – 1.2"
3. Drainage slots – 18 "V" shaped.
4. Six bosses to accept studs on flange.

D. Backflow Seal (UFlow Seal):

1. Mechanical compression seal.
2. Made of Polyamid and EPDM rubber.

3. Required for activation – a UFlow Screwdriver

E. Nuts and Screws:

1. Six stainless steel locknuts for the studs.
2. Three stainless steel screws to attach strainer to clamping ring.

2.03 ACCESSORIES

A. UFlow Screwdriver: A 12 ½" long shaft with a #2 square socket tip designed to reach the base of the drain stem to activate the backflow seal (UFlow seal).

B. DrainGuard: A 3" x 3" or 4" x 4" aluminum fixture, 4" high with drainage slots, adhered to the roof system designed to surround the drain and help prevent blockage of the drain strainer.

PART 3 EXECUTION

3.01 PREPARATION

A. Remove the clamping ring, strainer dome and bolts from the existing drain assembly and dispose of/recycle.

B. The existing drain leader pipe shall be cleaned of bitumen, dirt and any other debris.

3.02 INSTALLATION

A. Install the OlyFlow Hercules RetroDrain with Aluminum Dome into the existing drain leader as per the installation instructions.

B. Install the flashing material into place per the primary roofing manufacturer's recommended detailing, and per the drawings.

C. Installation is complete after flashing material is installed.

3.03 WARRANTY

Provide 1 year contractor's warranty for installation.

3.04 CLEAN UP

A. Remove all packing material and extraneous material used for installation from site.

END OF SECTION

SECTION 077110: SHEET METAL FLASHING AND COPING SYSTEM

I. PART ONE GENERAL

1.01 SUMMARY:

A. Work included: Furnishing and installing factory fabricated and finished coping systems.
Furnishing and installing sheet metal counter flashing.
Shop or field-formed sheet metal work for moisture protection
Miscellaneous sheet metal accessories.

B. Related Work Specified Elsewhere:

1. Built-Up Asphalt Roofing Section 075110
2. Sealant Section 079100

1.02 REFERENCES:

A. SPRI Sheet Membrane and Component Suppliers to the Commercial Roofing Industry, 175 Highland Ave., Needham, MA 02194, 617-444-0242, fax: 617-444-6111.

B. ASTM B209 – Standard Specification for Aluminum and Alloy Sheet and Plate

C. NRCA (National Roofing Contractors Association) – Roofing Manual

D. SMACNA – Architectural Sheet Metal Manual

1.03 SUBMITTALS:

A. Product Data: Provide manufacturer's product and complete installation data for all materials in this specification.

B. Shop drawings: Show profiles, joining method, accessories location, anchorage and flashing details, adjacent construction interface, and dimensions. Submit shop drawings showing layout joining, profiles and anchorages of fabricated work, including but not limited to counter flashings, gravel stops, trim/fascia units, scuppers and expansion joint systems.

C. Samples: Provide color selection chart, and actual metal samples of selected colors. Three metal color samples to be provided. Minimum dimensions 4x4 inches.

D. Contract Closeout: Submit Special Warranty and Manufacturer's performance certifications for coping.

E. Installation Guide: The product manufacturer shall provide a written installation guide.

1.04 QUALITY ASSURANCE- COPING:

A. High performance coping shall be CERTIFIED by the coping manufacturer to meet performance design criteria according to the following test standards:

1. ANSI/SPRI ES-1 Test RE-3 for Coping: The coping system shall be tested simultaneously on horizontal and vertical surfaces and shall exceed horizontal and vertical design wind pressure as calculated in accord with the ANSI/SPRI ES-1 Test RE-3. Use the current edition of ANSI/SPRI ES-1 Wind Design Standard for Edge Systems Used with Low Slope Roofing Systems.

2. The coping product shall be UL Classified by Underwriters Laboratories, Inc.® or other 3rd party verification of compliance with the ANSI/SPRI ES-1 Wind Design Standard.

B. Sheet metal for flashing shall be the same material as that used for coping, and match the coping color.

C. Rolled soft metal flashing shall be of a type and gauge acceptable for use by the roofing industry.

1.05 PRODUCT HANDLING:

A. All materials shall be delivered in the manufacturer's original sealed, labeled containers.

B. Store materials in a dry, protected, well-vented area. The contractor shall report damaged material immediately to the delivering carrier and note such damage on the carrier's freight bill of lading.

C. Remove protective plastic surface film immediately after installation [if applicable].

1.06 SUBSTITUTIONS

A. Proposals for substitution products shall be accepted only from bidding contractors a minimum of 10 working days before bid due date. The proposed substitution shall meet the performance and quality standards of this specification.

1.07 JOB CONDITIONS:

A. Verify that other trades with related work are complete before mounting coping covers.

B. Mounting surfaces shall be straight and secure; substrates shall be of proper width.

C. Refer to the construction documents, shop drawings and manufacturer's installation instructions.

D. Coordinate installation with roof membrane manufacturer's instructions before starting.

1.08 WARRANTY/GUARANTEE:

A. Manufacturer's Standard Warranty for COPING: Warranted materials shall be free of defects in material and workmanship for five years after shipment. If, after inspection, the manufacturer agrees that materials are defective, the manufacturer shall at their option repair or replace them. For decorative finish warranty, consult manufacturer.

B. Standard 20-Year Roof Edge System Warranty: Manufacturer shall guarantee that a standard size roof edge system, when installed per manufacturer's instructions, will not blow off, leak, or cause membrane failure, even in wind conditions up to 110 mph, or the manufacturer shall at their option repair or replace their materials.

II. PART TWO PRODUCTS

2.01 COPING MANUFACTURERS:

A. W. P. Hickman Company, P.O. Box 15005, Asheville, NC 28813-0005
Phone: 828-676-1700, Toll Free: 800-892-9173, Fax: 828-676-2330
Internet address - http://www.wph.com

B. FLEX COPING, 2670 Leiscz's Bridge Road, Suite 400, Leesport, PA 19533
Phone: 610-916-9500, FAX 610-916-9501

C. DERBIGUM AMERICAS, Inc., 4800 Blue Parkway, Kansas City, Mo 64105
Phone: 800-727-9872, FAX 816-924-1542 www.derbigum.com

D. Or Approved equal.

2.02 PARAPET COPING SYSTEM:

A. Hickman Permasnap Coping: Metal coping cap with 20 ga. galvanized steel anchor cleats with .063 aluminum with precoat Kynar 500, color from manufacturer's standard color chart. Four inch legs. Able to withstand wind speed of a maximum of 110 miles per hour, meeting FM 1-180. Fasteners to be stainless steel screws type with minimum pullout resistance of 240 pounds. The system shall be watertight, maintenance free, and not have any exposed fasteners. Joints shall be butt type with concealed splice plates.

B. FLEX Cap Coping Type FLC: Metal coping cap with 20 ga. galvanized steel anchor cleats with .063 aluminum with precoat Kynar 500, color from manufacturer's standard color chart. Four inch legs. Able to withstand wind speed of a maximum of 110 miles per hour, meeting FM 1-180. Fasteners to be stainless steel screws type with minimum pullout resistance of 240 pounds. The system shall be watertight, maintenance free, and not have any exposed fasteners. Joints shall be butt type with concealed splice plates.

C. DERBIGUM Perlok 90 Fascia: Metal coping cap with 20 ga. galvanized steel anchor cleats with .063 aluminum with precoat Kynar 500, color from manufacturer's standard color chart. Four inch legs. Able to withstand wind speed of a maximum of 110 miles per hour, meeting FM 1-210. Fasteners to be stainless steel screws type with minimum pullout resistance of 240 pounds. The system shall be watertight, maintenance free, and not have any exposed fasteners. Joints shall be butt type with concealed splice plates.

2.03 PARAPET PERFORMANCE CHARACTERISTICS:

A. Coping sections shall expand and contract freely while mechanically locked in place on anchor cleats.

B. Coping sections shall lock to anchor cleats my mechanical pressure from support chairs.

C. All coping cover joints shall be underplayed with gutter/support chairs capable of draining water.

D. Coping cap lengths of 10'-0" and custom widths.

E. Coping vertical face and back leg standard 4 inches.

F. Internal splice plats shall be concealed with matching finish to maintain outside face continuity.

G. Coping cleat to be 20 ga galvanized steel anchor, normally 12" wide at 5'-0" on center, to me mechanically fastened as indicated and detailed, per manufacturer's specifications.

H. Gutter/support chair to be metal in color and finish to match coping cap.

I. Fasteners to be stainless steel screw type, 240# pull out minimum resistance, as supplied by manufacturer. No exposed fasteners shall be permitted.

J. Color to be selected by ARCHITECT from standard Kynar-500 colors. Provide actual samples of a minimum of 3 colors as selected by Architect for final selection.

2.03 COPING CAP ACCESSORIES:

A. Corners, end caps, pier caps, etc. shall be fabricated by the coping manufacturer, same gauge and finish as cap.

B. Welded or METAL-LOCK® assembly shall be used to maintain watertight integrity.

2.04 SHEET METAL FLASHING AND ACCESSORIES

A. Same material as coping cap, thickness and color.

B. Fasteners to be stainless steel.

C. Shop fabricate work to greatest extent possible; comply with details and applicable requirements of SMACNA Architectural Sheet Metal Manual.

III. PART THREE - EXECUTION

3.01 INSPECTION:

A. Verify that coping and flashing counterflashing and miscellaneous metals installation will not disrupt other trades. Verify that substrate is dry, clean and free of foreign matter. Report and correct defects prior to any installation.

3.02 INSTALLATION:

A. Submit product design drawings for review and approval to Architect or Specifier before fabrication.

B. Installing contractor shall check as-built conditions and verify the manufacturer's coping details for accuracy to fit the wall assembly prior to fabrication. The installer shall comply with the coping manufacturer's installation guide when setting copings.

C. Installer shall use mechanical fasteners with minimum 240 # (109 kg) pull-out resistance suitable for parapet substrates.

D. Comply with recommendations in SMACNA Architectural sheet metal.

E. Anchor units of work securely in place by methods indicated, providing for thermal expansion of metal units, set units true to line and level.

F. Install work with laps, joints and seams that will be permanently watertight and weatherproof. Drip edge flashing shall be provided with concealed spliced plates.

G. Bed flanges of work in a thick coat of bituminous roofing cement where required for waterproofing performance.

H. Provide for separation of metal from non-compatible metal or corrosive substrates by coated concealed surfaces at locations of contact, with bituminous coating or other permanent separation as recommended by manufacturer/fabricator.

3.03 CLEANING AND PROTECTIONS

A. Clean exposed metal surfaces, removing substances that might cause corrosion of metal or deterioration of finishes.

END OF SECTION

SECTION 079100 CAULKING AND SEALANTS

PART 1 –GENERAL

1.01 RELATED DOCUMENTS

A. Division 0 and 1, as listed in the Table of Contents, apply here.

B. Refer to other Sections of these Specifications to determine the type and extent of work therein affecting the work of this trade whether or not such work is specifically mentioned in this Section.

C. Provide a copy of all applicable Drawings, including Shop Drawings, and Specifications at the site during all work.

1.02 SUMMARY

A. Refer to Section 01011—Project Description—for the scope of work included in this Section. Section includes removal of any existing sealant, cleaning of existing concrete and installation of new sealant, including priming, joint backing, tooling and testing.

B. Work related to this section includes, but is not limited to, the following:

1. Built-Up Asphalt Roofing Section 0751101
2. Sheet Metal Flashing and Coping System Section 077110

C. Follow sequence of work in Summary, Section 01010.

1.03 REFERENCES

A. American Society for Testing and Materials (ASTM):

1. ASTM C639 – Standard Test Method for Rheological (Flow) properties of Elastomeric Sealants.

2. ASTM C679 – Standard Test Method for Tack-Free Time of Elastomeric Sealants.

3. ASTM C719 – Standard Test Method for Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement (Hockman Cycle)

4. ASTM C794 – Standard Test Method for Adhesion-in-Peel of Elastomeric Joint Sealants.

5. ASTM C920 - Elastomeric Joint Sealants

6. ASTM C1135 – Standard Test Method for determining Tensile Adhesion Properties of Structural Sealants.

7. ASTM C1193 – Standard Guide for Use of Joint Sealants.

1.04 SUBMITTALS

A. Submit in accordance with Section 01300 – Submittals.

B. Product data for silicone sealants, primers, joint backing cleaning solvents, and other accessories. Include material safety data (MSDS) sheets and certifications showing compliance with specified standards.

C. Shop drawings detailing renovation sealant joints and indicating dimensions, materials and profiles.

D. Manufacturer's sealant color chart for selections by Architect.

E. Manufacturer's instructions for removal, joint preparation, repair and replacement.

F. Copy of manufacturer's warranties.

1.05 QUALITY ASSURANCE

A. Applicator Qualifications:

1. Applicator shall have a minimum of 3 years experience in application of silicone sealants.

2. Applicator to provide names of Owner of three buildings, and contact information: where silicone sealant was applied by applicator.

B. During construction period each type of sealant and related primer and backing shall be products provided by a single manufacturer.

1.06 PRE-INSTALLATION ADHESION TEST

A. Prior to application of sealants, test each renovation condition to ensure that sealants satisfactorily adhere to substrate.

B. Conduct test in field of by submission of representative substrate sample to manufacturer for factory test.

C. Apply sealant to sample substrate and perform hand-pull tab test in accordance with ASTM C-1193, Method A.

D. Determine if primer is required. If so, re-test using primer.

E. Submit report to Architect with description of test, results, and recommended installation procedures to obtain proper adhesion.

1.07 FIELD SAMPLE

A. Renovate a typical sealant joint to illustrate method, workmanship, adhesion, weatherproofing, tooling and appearance.

1. Minimum length 6 feet.
2. Accepted sample may remain as part of work, and will be used as a basis for acceptance of remaining sealant work. Unacceptable samples shall be removed.

1.08 PRE-INSTALLATION CONFERENCE.

A. Meet at the site after the preconstruction meeting, but before installation of sealant is to proceed.

B. Attendees to include persons directly concerned with sealant renovation, including contractor and subcontractor, Architect and City representative.

C. Review:

1. Schedule for installation of sealants and coordination with other renovation work items.

2. Protection of installed items and finishes.

3. Approved field sample to be used as a measure of acceptance.

4. Weather conditions forecast.

5. Other items related to successful execution of work.

1.09 PRODUCT HANDLING

A. Deliver products in manufacturer's original containers clearly labeled with product identification, date of manufacture, and shelf life.

B. Store materials in a clean, dry area at temperatures below 86 degrees F. and above 50 degrees F.

C. Do not use sealants and primers after manufacturer's stated shelf life.

1.10 PROJECT CONDITIONS

A. Do not install silicone sealants during inclement weather or when such conditions are expected within 24 hours. Allow wet surfaces to dry.

B. Sealant application temperatures are between 50°F and 95°F.

C. Do not install sealants when temperature is 5° F below dew point.

1.11 WARRANTY

A. Provide installer's 5 year workmanship warranty.

B. Provide manufacturer's 1 year material warranty for properly installed products.

PART 2 PRODUCTS

2.1 ACCEPTABLE MANUFACTURERS

A. GE Construction Sealants, 9930 Kincey Avenue, Huntersville, NC 28078, 877 943-7325; Tremco Commercial Sealants and Waterproofing, 3735 Green Road, Beachwood, OH 44122, phone 800 321-7906; Dow Corning Corporation, Corporate Center, P.O. Box 994, Midland, MI 48686, phone 800 248-2481.

B. Approved equal.

2.2 PRODUCTS

A. Sealant between metal roof flashing and concrete walls

1. Sealants

a. Dow Corning 790

b. Tremco Spectrem 1

c. GE Silpruf LM

d. Approved equal

2. Primer- per manufacturer's recommendation.

3. Surface cleaner- Denatured alcohol or as otherwise required by sealant manufacturer to obtain optimum adhesion.

4. Bond Breaker Tape - 0.006 inch thick polyethylene, to which sealant does not bond, adhesive-backed on one side, width as required.

PART 3—EXECUTION

3.01 JOB-SITE TESTS

A. One 6 foot long section, tooled per plans, to be shown to City of Milwaukee inspector. Inspector shall determine if installation is acceptable. In the event it is not found acceptable, the contractor shall cut out the sealant, clean the joint, apply primer as needed, and reseal. New application shall be subject to City of Milwaukee inspector approval.

B. If any sample debonds from the substrate, the sealant manufacturer shall make recommendations regarding changes in surface preparation or primers, and submit these recommendations to the City for review. Repeat sealant adhesion tests as many times as required to produce an acceptable allocation at no additional cost to the Owner and with no delays to the project schedule.

3.02 SEALANT INSTALLATION

A. Preparation

1. Remove any existing sealant, dirt and /or other foreign substances from surfaces to receive sealant. All surfaces shall be dry before preparation begins. The solvent cleaning preparation is to be done immediately before installation of sealant.

2. Solvent cleaning for metal surfaces: Use two clean, white, soft, lint-free cotton cloths and clean, fresh denatured alcohol and other solvents as required to clean metal and the nonporous surfaces. Wet one cloth with solvent and wipe surface vigorously Use second cloth to clean surface before solvent evaporates. Pump solvent from cans onto first cloth. Do not dip cloth in solvent, to avoid contamination of solvent. Repeat this two- cloth procedure until surface does not discolor cloth, and repeat at least once Do not solvent clean at temperatures below 45° F.

B. Apply Primer

1. Apply primer to all substrates as recommended by manufacturer. Apply primer to clean, dry substrates at ambient temperatures above 45° F.

2. Pour primer into a clean container for use. Do not pour more than a ten-minute supply into container to prevent deterioration.

3. Replace cap on primer can immediately after pro9uring. Remove from the site any primer that contains a white precipitate or that has thickened.

4. Apply primer with a clean brush. Do not apply primer to exposed surfaces beyond sealant. Mask all surfaces before priming, except where surface irregularities will allow the primer to wick beneath the masking tape. Use only one coat of primer. Do not apply primer in a thick layer, which will form a white, powdery film. Remove any films with a clean, dry, lint-free cloth, and repair in accordance with manufacturer's written recommendations.

5. Allow primer to dry. Do not allow primer to become wet before sealant application.

C. Install Sealant

1. Do not prepare or seal over masonry that is less than twenty-one days old or was repointed within twenty-one days.

2. Inspect each cartridge or container of sealant before use and verify that the production date is within six months of the date of application. Remove from the site all sealant more than six months old. Each applicator shall understand the method of decoding the production date on the cartridge or container.

3. Mask all exposed surfaces not masked for priming, along joints before applying sealant.

4. Apply sealant only to clean, dry, primed surfaces (where required) at ambient temperatures above 45° F. Seal joints within 10 hours of primer application.

5. Fill all joints solidly and continuously with sealant, neatly applied with a standard caulking gun in a continuous motion, using a slight pressure. "Push" the sealant bead ahead of the nozzle; do not "drag" the nozzle.

6. Within five minutes of sealant application and before skin develops on sealant, dry tool the joint surface with a concave tool to ensure intimate contact with substrate and to eliminate air bubbles. Do not use any liquid for tooling. Provide a smooth, uniform finished surface.

7. Remove masking tape within ten minutes of tooling. Avoid contaminating adjacent surfaces with excess sealant. Remove all traces of smears and droppings on metal or glass surfaces promptly, using a solvent recommended by the sealant manufacturer that will not damage or discolor the building surfaces. Remove smears and droppings on porous surfaces m mechanical means after cure of the sealant

8. Coordinate work with other trades to prevent contamination of fresh sealant by dust or other debris.

END OF SECTION